

GUJARAT INDUSTRIES POWER COMPANY LIMITED
(Surat Lignite Power Plant)
AT & POST NANI NAROLI, TALUKA: MANGROL, DIST: SURAT, PIN 394112 (GUJARAT)
Phone Nos.: EPABX (02629) 261063 to 261072, fax Nos.: (02629) 261112, 261080

TENDER DOCUMENTS FOR :

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

TENDER TITLE.: SLPP/BMD/SB/2025-26

TENDER NO - 2400153

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

INDEX

<u>Sr. No.</u>	<u>PARTICULARS</u>	<u>PAGE NO.</u>	
		From	To
(1)	NOTICE INVITING TENDER (NIT)	3	3
(2)	SECTION – A (INSTRUCTIONS TO BIDDERS)	4	26
(3)	SECTION – B (INSTRUCTIONS TO BIDDERS FOR ONLINE TENDERING)	27	27
(4)	SECTION – C (GENERAL CONDITIONS OF CONTRACT)	28	42
(5)	SECTION – D (SPECIAL CONDITIONS OF CONTRACT)	43	47
(6)	SECTION- E (SCHEDULE OF QUANTITIES & RATES)	48	48
(7)	SECTION- F (ANNEXURES AND FORMS)	49	62

NOTE: All the Bidders should study entire Tender documents carefully & may carry out Plant visit before quoting & submitting their online Bid to understand scope of work and its importance.

TENDER NOTICE (NIT)

Name of work	“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”
Place of work	Surat Lignite Power Plant - 4X125 MW, Unit # I to IV: Village: Nani Naroli, Taluka: Mangrol, Dist.: Surat (Gujarat).
Quantity	The successful lowest bidder will be awarded this contract, involving total quantities of various items as mentioned against item descriptions in Price Schedule (Annexure-F1)
Period of Contract	12 Months from date of issue of work order
EMD	Rs. 14,000/- (Rupees Fourteen Thousand Only) to be paid only by RTGS/NEFT/IMPS/Net Banking/Online Mode. In case of Bank Guarantee, the BG shall be in favour of GIPCL from approved Banks mentioned in this tender.
Tender fee	Rs. 2950 / - (Rupees Two thousand Nine Hundred Fifty only) non-refundable & 18% GST inclusive to be paid only by RTGS/NEFT/IMPS/Net Banking/Online Mode
Availability of online Tender document	On GIPCL’s E-Tender portal: https://etender.gipcl.com/ (for viewing and downloading Tender Document)
Downloading of online tender document from websites	04.03.2025 On GIPCL’s E-Tender portal: https://etender.gipcl.com/ (for viewing and downloading Tender Document)
Last date & Time of online submission of offer	25.03.2025, 17.30hrs https://etender.gipcl.com/
Submission of EMD and other supporting documents for prequalification bid in physical form	EMD and other documents to be submitted in physical form within or before due date of closing of the tender during office hours at office of Surat Lignite Power Plant, Nani Naroli, Dist. Surat.

NOTES:

1. Amendment / corrigendum of the tender document, the forms, schedules etc. may be done any time by the GIPCL during the period of publication of tender in the website. The bidders are required to visit the website regularly till the last date of bid submission.
2. GIPCL reserves the right to reject any or all the tenders or **split** the work among the bidders without assigning any reason thereof.
3. The bidders are required to quote the rate strictly as per the terms and conditions mentioned in the tender document. The conditional tender will not be entertained and shall be liable for outright rejection.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

4. The bidders are required to submit their bids online only, through the website GIPCL's E-Tender portal: <https://etender.gipcl.com/>
5. The EMD & other documents to be submitted in physical form only at the following address:
-

ADDL. GENERAL MANAGER – O & M
GUJARAT INDUSTRIES POWER CO. LTD.
(Surat Lignite Power Plant)
Village – Nani Naroli, Taluka – Mangrol,
District – Surat 394 112, Gujarat.
Phone: 02629-261063 (10 lines)
Email : bggajjar@gipcl.com

**GUJARAT INDUSTRIES POWER COMPANY LIMITED
SURAT LIGNITE POWER PLANT**

Subject: Open tender through GIPCL e-tender portal for “**Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26**”.

SECTION - A : INSTRUCTIONS TO BIDDERS

1. PLANT SYNOPSIS

Gujarat Industries Power Company Limited (GIPCL) (henceforth be named Company/GIPCL), is a Premier Power Utility in the State of Gujarat with an installed capacity of 1184.4 MW comprising of various conventional and renewable projects.

GIPCL commissioned its first power project; a 145 MW gas based combined cycle power plant in 1992 at Vadodara. It expanded its capacity by 165 MW Naptha and gas based Combined Cycle Power Plant at Vadodara in 1997. GIPCL has commissioned 1 MWp Distributed Solar Power Projects at two locations in Gujarat viz. at Village: Amrol, Dist.: Anand and at Village: Vastan, Taluka Mangrol, Dist.: Surat.

Surat Lignite Power Plant (SLPP) with four units of 125 MW capacity each is located at Village: Nani Naroli, Taluka: Mangrol, District: Surat in Gujarat. GIPCL has also operating its own captive Lignite and Lime Stone Mines close to the Power Plant. The Power Plant is based on Circulating Fluidized Bed Combustion (CFBC) technology for the Boilers, where Lignite is burnt along with Lime Stone in the Combustor of the Boiler.


It commissioned 5 MW solar power station at SLPP in 2012. Also, GIPCL has commissioned 1 MWp Distributed Solar Power Projects at two locations in Gujarat viz. at Village: Amrol, Dist.: Anand and at Village: Vastan, Taluka Mangrol, Dist.: Surat.

GIPCL has successfully commissioned a 2 x 40 MW Solar Project in 2017 as well as a 75 MW Solar Power Project in 2019 at Gujarat Solar Park, Village Charanka, Dist.: Patan. GIPCL has also successfully commissioned 112.4 MW wind farms at different location of Gujarat. The Company has commissioned the 100 MW Solar Project at the Raghanesda Solar Park, Banaskantha, Gujarat .

The Company has also been allotted land for development of a 2375 MW Renewable Energy Park at Khavda in the Kutch district of Gujarat

Surat Lignite Power Plant (SLPP) is accessible by road from Kim and Kosamba, which are on Mumbai-Ahmadabad highway. From Kosamba, SLPP is around 32 KM, out of which 27 KM is part of the National & State Highway and balance 5 KM is District Road. From Kim, SLPP is around 18 KM, out of which 13 KM is the State Highway and balance 5 KM is District Road. The nearest Broad Gauge Railway Line is at Kim, which is around 21 KM from the SLPP. Surat is approximately 50 KM from the SLPP. Location Map for SLPP is as under.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.



The Company intends to award Contract for “Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26” and is therefore inviting **Open tender through GIPCL e-tender web portal (E-Tender portal: <https://etender.gipcl.com/>)** from experienced & resourceful contractors.

2. GENERAL INSTRUCTIONS

The Bidders who are interested in participating in the tender must read and comply with the instructions and the terms and conditions contained in the tender documents.

The bids shall be filled in by the tendered clearly, neatly and accurately. Any alteration, erasures or over-writing would be liable to make the tender invalid unless the same is neatly carried out and attested over the full signature of tenderer. The decision of the Company to interpret the information and rates filled in by the tenderer shall be final and binding on the bidder.

The Bidders are requested to make themselves fully conversant with the General Conditions of Contract, Special Conditions of Contract, Technical Specifications, site conditions, safety and health aspects and norms to be observed, etc. while submitting their bids so that no ambiguity arises in these respects subsequent to submission of the Bids.

Before quoting the rates, the Bidder should go through the specifications, scope of work etc. and get himself fully conversant with them. The bid should include cost of mobilization and cost to adhere to all safety norms as described in the tender. No relaxation or request for revision of quoted/accepted rates shall be entertained subsequent to the opening of bid on account of mobilization or Safety costs.

Bidder has to submit all the information and details required in the bid document. Failure to furnish all the information as per required bid documents or submission of a bid containing deviations from the contractual terms and conditions, specifications and requirements shall be rejected.

The bids shall be submitted within the time frames set out in the Notice Inviting Tender (**‘NIT’**) and bids submitted thereafter shall not be accepted and considered.

The tender documents shall not be transferable.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

The Bidders are expected to examine all instructions, forms, terms and specifications in the bid documents and to get fully acquainted themselves with all the conditions and matters which may affect the subject matter of the work/tender or the cost thereof. If any Bidder finds any discrepancies or omissions in the specifications and documents or any doubt in true meaning or interpretation of any part, he shall seek necessary clarifications in writing if required.

Conditional offers shall not be considered and liable to be rejected.

The Company reserves the right to extend the deadlines for submission of the bids by giving amendments.

During evaluation of bids the Company may, at its discretion ask the bidder (s) for clarification of their bid. The request for clarification and the response shall be in writing and no change in prices or substance of the bid shall be sought, offered or permitted.

The Company reserves the right to amend/ modify the bidding documents at any time prior to the deadline for submission of bids, either at its own discretion or in response to the clarification requested by a prospective Bidder. In such case, the Company may in its discretion extend the deadline for submission of bids in order to facilitate the prospective Bidders for incorporating the effect of the amendment in their bids.

The Bidders shall bear all costs and expenses associated with the preparation and submission of their respective bids, to attend meetings or conferences, if any; including any pre award discussion with the successful Bidder, technical and other presentations, etc. and the Company shall not be liable for any expense thereof.

If the successful bidder is consortium / joint deed of undertaking of company, the consortium leader / bidder shall accept joint and several responsibilities and liabilities for all obligation under the contract.

Timely and satisfactory completion of the work and strict adherence to the allotted time frames for jobs shall be the essence of the contract.

The Company reserves the right to qualify/disqualify any applicant without assigning any reason.

The Bidder shall be disqualified if any untrue statement or misrepresentation is made in the bid forms, attachments and other supporting documents submitted by the Bidder.

3. Detailed scope of work

Detail scope of work constitutes of following parts.

- A) Mobilization / De-mobilization of resources (manpower, tools & tackles and consumables) for servicing of in boilers of Two Units during AOH.
- B) Complete servicing of Long Retractable Soot Blowers & Half Retractable Soot Blowers in boilers of Two Units during AOH.
- C) Mobilization/ De-mobilization for Inspection, required servicing and replacements of components of LRSB & HRSB (Total 144 nos. Soot blowers, Site work for at least 07 days with minimum 01 Service engineer + 03 technicians) in all four Units during FSD / as & when required.

Note:- Mobilization for AOH of boilers of Two Units shall be considered as separate mobilizations.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

PART- A : Mobilization / De-mobilization of resources

For Inspection and servicing of Long Retractable soot blowers & half retractable soot blowers, party has to mobilize resources as follows.

It includes mobilization of manpower along with necessary tools & tackles. Contractor has to mobilize sufficient quantity of require materials, material shifting and lifting arrangements, cleaning equipment etc. for complete servicing of Long Retractable soot blowers & half retractable soot blowers in Unit no 1 & 4 boiler requirement basis. It also includes mobilization of necessary consumables etc. Party has to mobilize sufficient tools & tackles with a backup arrangement for breakdown of any machine.

Contractor has to arrange skilled, semiskilled and unskilled manpower, technician for carrying out soot blower servicing work. Party has to mobilize all necessary safety equipment, PPE's etc. required for carrying out the inspection and servicing of Long Retractable soot blowers & half retractable soot blowers in boilers of Two Units during AOH.

Part B : Complete servicing of LRSB & HRSB of Unit-2 & Unit-3 boiler :

Inspection and servicing of Long Retractable soot blower & Half Retractable soot blowers in boilers of Two Units during AOH requirement basis work will be carried out by the party in identified area as per instruction of Engineer in charge (E-I-C).

Detail scope of work for Inspection and servicing of Long Retractable soot blower & half retractable soot blowers of boilers of Two Units during AOH requirement basis is as below.

- a. Party shall prepare bar chart for execution of work and submit to owner within one day of Inspection and servicing of Long Retractable soot blower & half retractable soot blowers. Inspection photographs of all above areas are required to submit to GIPCL.
- b. Care should be taken to avoid any damage to tubes or shell or duct or line or header etc... while Inspection and complete servicing of Long Retractable soot blower & half retractable soot blowers.
- c. Shifting of dismantled scrap to ground floor & at temporary scrap yard area marked by EIC. From temporary scrap yard scrap is to be shifted to scrap yard as per instructions of EIC within three days after completion of works.
- d. Contractor has to shift require all material from warehouse.
- e. Party has to arrange sufficient number of skilled & unskilled manpower for executing the job on round the clock basis for Inspection and complete servicing of Long Retractable soot blower & half retractable soot blowers
- f. Party has to execute the work and submit the report to GIPCL.
- g. The scope of work also includes the erection of temporary supports, required lifting arrangements for works as per the site requirements. No separate payment will be done on this account
- h. The quantity of Inspection and servicing of Long Retractable soot blower & half retractable soot blowers as per attached **Annexure F1**.
- i. Quantity mentioned above may be utilised for any unit of the SLPP.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- j. Party has to make joint protocol with detail report. Party has to submit this detail report along with the invoice which is mandatory for processing of invoice.
- k. The payment will be done as per actual execution of quantity. The bid submitted by the bidder not covering the total scope of work and services as detailed out in the tender document shall be liable for rejection.
- l. Party shall have to work as per availability of work front during execution of AOH / FSD / Running unit. Party shall have to work parallelly with other agencies also as per instruction of EIC to meet overall schedule of jobs.

There are LRSB (Model - LRD 1E) & HRSB (Model - HRD 1E) installed in Back pass / CP pass in each boiler. **The scope of work for each soot blower (LRSB &HRSB) broadly covers:**

I. Inspection and Complete Servicing of SBV head assembly

- a) Removal & Dismantling of SBV head assembly.
- b) Thoroughly cleaning & inspection of all internals.
- c) If required; lapping of body seat & disc.
- d) Replacement of gland packing, gaskets.
- e) Servicing/Replacement of all defective spares like Stem cap, stem & disc assembly, spring, Retainer, Etc.
- f) Box up the SBV head assembly.

II. Inspection and Servicing of Carriage Housing Assembly

- a) Removal & Dismantling of Carriage Housing assembly.
- b) Thoroughly cleaning & inspection of all internals.
- c) Inspection and Servicing of spindle, gland plate assembly, gland plate, gland follower, Carriage chain connector, idler shaft, travel wheel axel, worm shaft, spacer, sprocket, etc. Replace the damaged parts.
- d) Inspection and servicing of bushings, bearings, etc. Replace the damaged parts.
- e) Inspection and Servicing of retainer ring, thrust ring, O ring, all circlips, keys, worm gear & worm, etc. Replace the damaged parts.
- f) Inspection and Servicing of all fasteners like nut, bolt, split collar pin, hexagonal screw caps, etc. Replace the damaged parts.
- g) Checking the grease quality & replace if required.
- h) Box up the Carriage housing assembly.

III. Inspection and Servicing of Power Pack – Rotary and Traverse Gear Box assembly

- a) Removal and Dismantling of Rotary and Traverse Gear box assembly.
- b) Thoroughly cleaning & inspection of all internals.
- c) Inspection and servicing of Gear housing, coupling gear, Cluster pinion, Spindle, Gear Retainer, shim assembly, Air vent-1/8" taper, etc. replacement of damaged parts.
- d) Inspection and servicing of all bearings, shafts, oil seals; replace the damaged parts.
- e) Box up & lubricate the gear box.

IV. Inspection and Servicing of Rear End Plate Assembly

- a) Removal and Dismantling of Rear End Plate assembly.
- b) Thoroughly cleaning & inspection of all internals.
- c) Inspection and servicing of chain tightener plate, shaft bearing, operating lever, coupling assembly, all sprocket, bearings, etc.
- d) Inspection and servicing of all fasteners & replace; if required. (Washer, Circlip, Spring, pin, nut, bolts etc)
- e) Lubricate the bearings.
- f) Box up.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

V. Inspection and Servicing of Lance & Feed tube

- a) Remove the puppet valve & dummy the flange.
- b) Removal and Dismantling of Lance tube.
- c) Thoroughly cleaning & inspection of all internals like lance flange, nozzle head, Lance diffuser, etc.
- d) Check the lance thickness at various locations by thickness gauge; if lance or feed tube is found damaged or wear out, replace it. If required cut the wear part of lance & weld the new lance of same length.
- e) Check the soot blower inner wall sleeves & replace it; if found damaged. clear the mouth; if found choked.
- f) Box up the lance, replace the gasket & glands.
- g) Remove the puppet valve dummy & fit the puppet valve.

VI. Inspection and Servicing of Rotary, Traverse and Jack Shaft Drive Chain assembly

- a) Removal and Dismantling of chain.
- b) Thoroughly cleaning & inspection of all internals like chain links, connectors, etc.
- c) Replace the damaged parts.
- d) Box up.
- e) Adjust the chain tension.
- f) Lubricate the chain.

VII. Inspection and Servicing of blowing adjusting bar & operating lever system & other components

- a) Thoroughly cleaning & inspection of blowing adjusting bar & operating lever system.
- b) Replace the damaged parts as well as other components.

VIII. Trial of Soot Blower

- a) After completion of all above works & box up of all parts, check soot blower for manual operation for smooth operation.
- b) After manual operation is found satisfactory, check the soot blower for electrical operation. The direction of rotation of soot blower is to be ensured & it should be anti-clockwise when viewed from rear end.

IX. Pressure setting of Soot blower

- a) Fix the pressure gauge in the SBV operating head.
- b) Check the blowing pressure by running the soot blower electrically with steam.
- c) Set the blowing pressure as per recommended blowing pressure.
- d) After soot blower is completely retracted, ensure that SBV is completely close so that there is no passing of steam.
- e) Remove the pressure gauge from the SBV operating head & put the dummy bolt.
- f) Pressure setting of soot blower is to be carried out after boiler put on load.
- g) If any other defects related to poor workmanship are observed during this checking, it shall be attended as per instructions of E-I/C.

X. Servicing of Soot blower during boiler outage (for soot blower which cannot be carried out during boiler running condition)

- a) This activity is to be carried out during the outage of boiler for those soot blowers which has get stuck up inside / jammed.
- b) After cooling down of boiler, check the soot blower from inside and remove the jamming.
- c) Pressure setting of soot blower is to be carried out after boiler put on load.
- d) If any other defects for the workmanship are observed during this checking, attend it as per instructions of E-I/C.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- XI. Pressure setting of soot blower is to be carried out after boiler put on load.
- XII. If any other defects for the workmanship are observed during this checking, attend it as per instructions of E-I/C.

Part C : Inspection for checking healthiness of all soot blowers and servicing of selected soot blowers of Unit- 1, 2, 3 and 4:

- i. Party shall mobilize team of sufficient manpower (minimum 01 Service Engineer + 03 technician) for at least 10 days at site. Manpower deputed at site shall be well experienced and competent for Soot Blower servicing work.
- ii. Detailed inspection of all soot blowers of Unit-1, 2, 3 and 4 (total 144 nos.) in all aspects as per following
 - Inspection of SBV head assembly, Carriage Housing Assembly, Power Pack – Rotary and Traverse Gear Box assembly, Rear End Plate Assembly, Lance & Feed tube, Rotary, Traverse and Jack Shaft Drive Chain assembly, blowing adjusting bar & operating lever system & other components etc.
 - Submit detailed report regarding defects, corrective measures, spares requirement etc. and submit to Engineer In-charge.
- iii. Cleaning, lubrication, tuning, setting, taking trail and ensure normal and healthy operation of all soot blowers of Unit-1, 2, 3 and 4.
- iv. Servicing of selected soot blowers as decided by Engineer In-charge, which require complete / minor overhauling or repair. This includes dismantling and complete servicing like: Complete Servicing of SBV head assembly, Carriage Housing Assembly, Power Pack – Rotary and Traverse Gear Box assembly, Rear End Plate Assembly, Lance & Feed tube, Rotary, Traverse and Jack Shaft Drive Chain assembly, blowing adjusting bar & operating lever system & other components, replacement of required spares, assembly, tuning, setting, taking trial and ensure smooth and normal operation of soot blowers.
- v. This work will be planned separately during non-AOH period for which separate mobilization/demobilization shall be required by contractor. Schedule for Part-C work will be decided by GIPCL based on site requirement / short outage of unit and intimation will be given to contractor for mobilization of team before 07 days.

Scope of Contractor:

- 1) GIPCL will give space for storing of material. Party has to arrange issue of material from warehouse. Party shall furnish day to day material conciliation report.
- 2) Mobilization of manpower and other resources as mentioned in detailed scope of work. Party shall also mobilize additional manpower and material and tools tackles within short notice, if required.
- 3) Require tools tackles for Inspection and servicing of Long Retractable soot blower & half retractable soot blowers work shall be arranged by contractor in sufficient quantity to meet requirement of the job in respective area.
- 4) Arrangements for lifting of material from ground floor to various floors shall be in contractor scope. Contract may utilize the hoist / lift provided at site subject to its availability. GIPCL will not be responsible for any delay due to non-working of hoist/lift, and contractor shall have to made his own arrangement in case hoist/lift is not in working condition.
- 5) All required Grinding machine, air hose, lighting arrangement, with all safety precaution.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- 6) Any other material and machines required for Inspection and complete servicing of Long Retractable soot blower & half retractable soot blowers.
- 7) Security & safety of contractor's material and the material issued by GIPCL shall be contractor's scope.
- 8) All tools and tackles including in situ lapping machine, lapping paste, blue ink for blue matching, etc required to execute the contract are in the scope of the contractor. The contractor should ensure that tools are in healthy condition.
- 9) Contractor has to arrange submit the detail report, all photographs, drawing, dimensions to GIPCL in hard copy and soft copy
- 10) All safety/PPEs required during work at site are to be arranged by the contractor.
- 11) The Contractor shall have to provide necessary facilities including accommodation for their labor at their own cost.
- 12) Contractor has to depute their full time experienced overall site-in-charge & independent Location/Package wise supervisors for work execution as per specification and for day to day work planning & coordination with respective department's Engineer-in-charge, to obtain day to day Location/Package wise work permits, to get daily location wise work supervision, to record Location/Package wise joint work done reports/measurements/trip certification, to prepare Location/Package wise separate bills, to prepare & apply Location/Package wise manpower gate pass, to maintain Location/Package wise statutory & legal compliance records, etc.

GUARANTEE PERIOD (FOR Part-B)

Guarantee period shall **four (04) months** from the date of completion of work and handing over of the equipment. Any defect arising during guarantee period shall be attended by party with their own material, manpower, tools & tackles free of cost.

MOBILISATION PERIOD

For Part A, B, C - GIPCL will give 7 days' advance notice for mobilization of resources to site for Soot Blower work during annual overhauling / shut down of unit. Contractor shall mobilize sufficient manpower and machine with necessary tools & tackles, within the time, to the site.

4. PLANT VISIT

The Bidder is advised and necessary for all interested bidders to visit the Surat Lignite Power Plant (SLPP) after downloading the tender copy from website: <https://etender.gipcl.com/> to study the actual working conditions, compliance related to labour, safety etc. before submitting their offer. The Bidders shall examine the site of works and its surroundings at his own responsibility. The Bidders shall collect information that may be necessary for preparing the Bid and entering into a contract. All costs and liabilities arising out of the site visit shall be at Bidder's account.

The Bidder is deemed to have examined and understood the tender document, obtained his own information in all matters whatsoever that might affect the works to be carried out especially mentioned or works which may have to be carried out to fulfil his contractual obligation within the scheduled rates and to have satisfied himself to the sufficiency for his offer.

The submission of tender by a contractor implies that he has visited the site and read these instructions, conditions of the contract etc. and has himself aware of the scope, nature of works & "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

specifications of the works to be done, General & Special terms and conditions. GIPCL will not, therefore after acceptance of contractor's rate, pay any extra charges for any other reason in case the contractor is found later on to have misjudged the site conditions.

Any error in description or quantity or omission in the contract document shall not vitiate the contract or release the contractor from executing the work comprised in the contract according to scope of works, magnitude of the works, requirement of materials, equipment, tools & tackles, labour, etc. Contractor has to complete the work in accordance with the contract documents irrespective of any defects, omissions or errors that may be found in the contract documents.

Bidder shall inspect the site, examine and obtain all information required and satisfy himself regarding matters such as access to site, communication, transport, working condition including constraint of work place, confined area, quantum of dusting, running equipment, importance of work, round the clock working conditions, safety requirements, temperature of fresh drained hot bed material, right of way, high flood level in River, flow of water during monsoon/dry season in the River/Nallah, the type and number of equipment and facilities required for the satisfactory completion of work, the quantity of various items of the work, the availability of local labour, availability and rates of material, local working conditions, uncertainties of weather, obstructions and hindrances that may arise, etc which may affect the work or cost thereof, before submission of his Bid. Ignorance of site conditions shall not be accepted by the GIPCL as basis for any claim for compensation. The submission of a Bid by the BIDDER will be construed as evidence that such an examination was made. Any later claims / disputes in regard to rates quoted shall not be entertained or considered by the GIPCL.

The rates quoted by Bidder shall be based on his own knowledge and judgment of the conditions and hazards involved and shall not be based on any representations of the Engineer.

5. ELIGIBILITY CRITERIA: -

The following criteria will be adopted for qualifying the Bidders for consideration of the Bid for the further proceeding.

5.1 Bidder should possess minimum three years of experience during last five year in Supply of LRSB HRSB spares or servicing of Long Retractable soot blower & half retractable soot blowers in lignite or coal fired units (Party should have similar type of servicing of LRSB & HRSB or Supply of soot blower spares in 100MW or more capacity boilers). Proof to be attached. Bidder shall submit necessary evidence for the same like self-attested copies of work order/ work execution / Work completion certificate from client. The work completion certificate shall comprise of order value & executed value. Bidder should have executed the work directly. The work order executed as a sub-contractor or subletting agency shall not be taken in to consideration.

5.2 Bidder should produce evidence of having experience of successfully completed identical works as defined hereunder during last three years of last five years ending last day of the month previous to the one in which tender is invited, satisfactory progress of ongoing works etc. along with certified copies of documentary evidence preferably photo copies of work experience from the clients. Secured from clients along with self-attested copies of documentary evidence preferably photo copies of work experience. The experience should be either of the following:

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Bidder should have executed minimum: (for Supply of soot blower spares or servicing of LRSB & HRSB in lignite or coal fired units in boiler (Party should have similar type of service or supply of soot blowers 100MW or more capacity boilers)

- A. One similar completed work each costing not less than the amount equal to 12.70 Lakh**
OR
- B. Two similar completed work each costing not less than the amount equal to 7.93 Lakh**
OR
- C. Three similar completed work each costing not less than the amount equal to 6.35 Lakh**

Bidder should specifically mention fulfilling of above criteria in the offer along with details of work orders / work completion certificates issued by clients

- 5.3 Tender fee: The Tender fee shall be paid through RTGS / NEFT / IMPS / Net Banking / Online Mode. Proof to be attached
- 5.4 EMD: The EMD shall be accompanied in the form of DD / RTGS or Bank Guarantee given by Bank as described in subsequent clause. Proof to be attached. EMD shall be paid through RTGS / NEFT / IMPS / Net Banking / Online Mode.
- 5.5 Bidder should have separate Employees Provident Fund code number towards registration of firm with RPF commissioner. Proof to be attached.
- 5.6 Attested copies of relevant documents duly signed & seal on each & every page shall be submitted. GIPCL may verify the documents, experience certificates issued by concern authority. After opening of technical Bid, if any required attested documents found missing in the Technical Bid submitted by the Bidder, the tender inviting authority may inform to that Bidder only once by E-mail to submit the missing required documents within stipulated time limit. If Bidder/Bidders fail to submit within stipulated time, their Bid will be declared technically disqualified and no further correspondence will be entertained. Copies of the same shall be submitted.
- 5.7 Bidder should have average annual turnover of **4.76 Lakh** for last three financial year **(2023-24,2022-23,2021-22)**. Bidder shall furnish annual audited financial statement duly certified by Chartered Accountant (Certified by/from a qualified Chartered Accountant, being a member of the Institute of Chartered Accountants of India) for the last three years to demonstrate the financial healthiness of the company. The balance Sheet and profit & loss account must be in the name of company. Any type of MOU for this purpose will not be entertained. Copies of the same shall be submitted.
Note – In case the annual turnover is less than the statutory guideline which does not require audit, the bidder shall submit the turnover certificate from chartered Accountant. (certified by/from a qualified Chartered Accountant, being a member of the Institute of Chartered Accountants of India)
- 5.8 The Bidder has to submit Income tax Permanent Account number (PAN) & GST registration number. Copies of the same shall be submitted.
- 5.9 The net worth of the bidder as on 31.03.2024 should be positive as evidenced from audited accounts.
- 5.10 In case Bidder is a Consortium / joint deed of Under taking of company, the above requirements / credential of consortium leader / bidder shall be considered unless otherwise specifically mentioned in tender.

The Contractor shall not directly or indirectly assign or sub-let total/any part of the contract to any other party or agency

Contractor has to submit satisfactory work completion certificate from the client. Experience as a sub-contractor will not be allowed and Price Bid of such Bidders will be rejected.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Bidder shall enclose P. F. code allotment letter along with labour licenses and W.C. Policy copies of previous orders.

ADDITIONAL PRE-QUALIFICATION CRITERIA

If Bidder or its Partner(s) or Director(s) is /are/was Black Listed / stopped or banned from dealing in the past by any Govt, of Gujarat Undertaking / Depts. / Authorities and Govt. of Gujarat supported companies / undertakings / organizations, bid of that party will be liable to be rejected. Bidder agrees and undertakes to accept decision of GIPCL in this regard as final and binding on the Bidder without any demur and that no further correspondence shall be done in this regard at any stage. Bidder shall have to submit the "Declaration-cum-Undertaking for Compliance of Safety Laws and Regulations" as amended in Annexure/ Form attached

Bidder shall have to submit the "Declaration-cum-Undertaking for Compliance of Safety Laws and Regulations" as amended in Annexure/ Form attached.

- a. If any Fatal Accident / Violation of any safety law(s) / Rule(s) is / are found during the preceding Three (3) years, bid of that party will be liable to be rejected. Bidder agrees and undertakes to accept decision of GIPCL in this regard as final and binding on the Bidder without any demur and that no further correspondence shall be done in this regard at any stage.
- b. If any of the details submitted in the prescribed Annexure / Form to the Bid is/are found to be false, incorrect at any time in future, then the Contract awarded to that Bidder / Contractor shall be liable to be terminated forthwith without any notice / correspondence and Bidder agrees and undertakes to accept decision of GIPCL in this regards as final and binding on the Bidder without any demur and that no further correspondence shall be done in this regard at any stage. Further, Performance / Security Deposit will also be liable to be forfeited. Any dues to GIPCL from the Bidder / Contractor shall be recovered from the pending bills or any other dues payable to the Bidder / Contractor, if any or otherwise through any other recourse available under the Laws.

The Bidder shall submit all the evidences, documents, attested copies of work orders & work completion certificates etc... as a proof with EMD & Tender Fee and also provide the requisite details online for meeting the prequalification requirements. GIPCL will verify the experience, performance, capability & strength of Bidders, independently for executing the job. GIPCL may visit the site & consult the owner of the industry/property where similar job is executed by Bidder. GIPCL reserves the right to accept/split/cancel/reject any/all Bids without assigning any reason thereof. The tenders of qualified Bidder/Bidders shall only be considered for further evaluation.

The Bidder shall enclose copy of all the documents, work orders and any other certificates to satisfy his eligibility criteria along with Annexure-I duly filled in.

6. LANGUAGE OF BID

The Bid prepared by the Bidder, and all correspondence and documents relating to the Bid exchanged by the Bidder and the Company, shall be written in the English language. Any printed literature furnished by the Bidder, written in another language shall be accompanied by an English translation for the purpose of interpretation of the Bid.

7. EARNEST MONEY DEPOSIT (EMD) & TENDER FEE

7.1. An EMD of **Rs. 14,000/-** (Rupees Fourteen Thousand Only) and Non-refundable Tender fee **Rs. 2950/-** (Rupees Two Thousand Nine Hundred Five Hundred only) shall "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

accompany with Bid. Tender fee & EMD shall be paid through RTGS / NEFT / IMPS / Net Banking / Online Mode

- 7.2. The EMD shall be submitted in the form of DD/irrevocable Bank Guarantee in favor of Gujarat Industries Power Company Limited from any Schedule Public Sector Bank or Schedule Private Sector Bank as per Performa of BG enclosed with this e-tender.

Alternatively, The EMD & Tender Fee may also be submitted through RTGS/online mode of payment by the bidders as per the details given below:-

Name of account holder	Gujarat Industries Power Company Limited
A/c. No.	33514692834
Name of Bank	State Bank of India
Address of Bank	Utility Building, Nani Naroli, Taluka Mangrol, Dist. Surat. Pin 394 110
IFSC code	SBIN0013423
MICR code	394002513

- 7.3. In case EMD is paid in the form of BG, the same shall be valid for a period of 180 days after the due date for submission of the bid
- 7.4. The EMD of the successful bidder will be returned after payment of Security Deposit by successful bidder.
- 7.5. The earnest money deposit will be refunded to the unsuccessful BIDDER as soon as the tender is finalized and after award of LOI/Work Order.
- 7.6. Any bid not accompanied with EMD and Tender fee will be rejected. Tender fees and EMD should be submitted to GIPCL.
- 7.7. No interest shall be payable on EMD.
- 7.8. The EMD will be forfeited if the BIDDER (i) withdraws his tender after acceptance or (ii) withdraws his tender before the validity date of the tender.
- 7.9. **SCHEDULE OF EMD & TENDER FEES**

EMD & Tender fee and other documents dully signed shall be submitted in physical form on or before due date of closing of the tender	Address for Submission: AGM (O&M)- SLPP GUJARAT INDUSTRIES POWER CO. LTD., (Surat Lignite Power Plant) Village – Nani Naroli, Taluka – Mangrol District – Surat 394 110, Gujarat Phone : 02629-261063 (10 lines) Email : bggajjar@gipcl.com
--	--

8. SUBMISSION OF BID

A: MODE OF SUBMISSION

The bids shall be submitted online at the GIPCL e-portal within the dates specified in the NIT along with the details of tender fees, Bid in two parts as under:

- a) Pre-Qualification bid and Techno-commercial bid without price
b) Price bid

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Note: Tender fee and EMD and other documents to be submitted in physical form within on or before due date of closing of the tender during office hours at office of Surat Lignite Power Plant, Nani Naroli, Dist. Surat.

(a) Pre-Qualification & Techno-commercial bid without price

The following documents shall also be submitted dully signed and stamp

The tender document duly signed in all pages without price bid along with techno-commercial deviations, if any shall accompany the bid. The following Information shall be provided in the techno commercial bid:

1. Qualification and experience of site in charge / site Engineers and supervisors.
2. Schedule of deviation (**Annexure- J**) Technical as well as commercial, if any.

The following supporting documents shall also be submitted along with EMD & Tender Fee in Physical form.

1. The tender document duly signed in all pages without price bid along with techno-commercial deviations, if any
2. Proof of experience meeting the minimum eligibility criteria as per tender Annexure I (Supporting documents to be must attached)
3. Performance certificate issued by clients
4. Previous work order copies
5. Present ongoing work details.
6. Turn over for the last three years, audited annual accounts / financial statements i.e profit and loss account and balance sheet duly certified by a practicing CA will be required
7. PF Number and Allotment Letter
8. PAN Number
9. Goods & Service tax registration number / Certificate copy
10. Annexure **I, M, N & L**

(b) Price Bid

1. Price Bid shall be submitted only in soft form GIPCL's Open E-Tender portal: <https://etender.gipcl.com/>
Note: Quoted rates includes cost of all manpower, equipment, vehicles, consumables, tools & tackles, transportation, Safety and statutory compliance, mobilization, Contingency expenditure and supervision charges etc.....
2. All taxes as applicable shall be paid extra at actual as per prevailing rates as declared by Central Government on submission of documentary evidence.
3. The quantities shown in the price Bid are approximate for the contract period and may vary as per job requirement.
4. The Bidder shall fill the Bid documents with utmost care in consonance with the instructions contained in the Bid documents.

B: METHOD OF TENDERING/SIGNATURE OF BIDS

The Bid must contain the postal address like name, residence and place of business of the person or persons submitting the Bid and must be signed and sealed by the Bidder with his usual signature. The name of all persons signing the documents shall also be typed or printed below the signature on each page.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Bid by a consortium/joint deed of undertaking of company / partnership firm must be furnished with full names of all partners and be signed with the partnership name, followed by the signature and designation of one of the authorised partners or other authorised representative(s). A certified copy of the power of attorney authorizing such partner or representative shall also be submitted.

Bids by a Corporation/Company must be signed with the legal name of the Corporation/Company i.e by the President/Managing Director/Secretary or other person or persons authorised to Bid on behalf of such Corporation/Company. A certified copy of the board resolution/power of attorney authorizing such partner or representative shall also be submitted.

The Bidder's name stated on the proposal shall be the exact legal name of the firm.

Erasures or other changes in the Bid Documents shall be initialled by the person signing the Bid.

Bids not conforming to the above requirements of signing shall be disqualified.

SCHEDULE OF DEVIATIONS

Whenever bidder deviates from the specifications the same shall be listed out in the "Schedule of Deviation" attached as **ANNEXURE-J** to these specifications. Only those deviations, which are listed in this Annexure, shall be considered. Deviations indicated elsewhere will be rejected.

9. MODIFICATION & WITHDRAWAL OF BID

- a) The Bidder may modify or withdraw the bid prior to the deadline prescribed for submission of bids.
- b) No Bid shall be modified subsequent to the deadline for submission of Bids.
- c) No Bid shall be withdrawn in the interval between the deadline for submission of Bids and the expiration of the period of bid validity.

10. POLICY FOR BIDS UNDER CONSIDERATION

- a) Bid shall be deemed to be under consideration immediately after opening of the bid and till official intimation of award/rejection made by the Company to the Bidders.
- b) While the Bids are under consideration, Bidders and / or their representative or other interested parties are advised to refrain from contacting by any means, the Company. The Engineer, if necessary, will obtain clarifications on the Bids by requesting for such information from any or all the Bidders, in writing as may be necessary. The Bidder will not be permitted to change the price or substance of the Bid after the Bid has been opened.

11. EFFECT & VALIDITY OF BID

- a) The Bid should be kept valid for acceptance for a period of one hundred and eighty (180) calendar days from the last date of submission of Bids.
- b) The submission of any Bid along with the required documents and specifications shall constitute an agreement that the Bidder shall have no cause of action or claim, against the Company for rejection of his Bid. The Company shall always be at liberty to reject or accept any Bid or Bids at his sole discretion and any action will not be called into question and the Bidder shall have no claim in that regard against the GIPCL.

12. OPENING OF BIDS

The GIPCL will open the pre-qualification/Technical Bid/price Bid, as the case may be, in presence of Bidder's representatives whenever such a procedure has been specified. Otherwise the tender will be opened by the authorized officers of GIPCL.

Preliminary Examination:

The Company will examine the Bids for any computational errors, for sureties furnished by bidder, for authentication of documents submitted and completeness of the Bids.

Arithmetical errors will be rectified on the following basis:

If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price will be corrected & will be binding to the bidders

If there is a discrepancy between the Total Bid Amount and the sum of total prices, the sum of total prices shall prevail and the Total Bid Amount will be corrected & will be binding to the bidders.

13. EVALUATION & COMPARISON OF BIDS

GIPCL shall evaluate the Bids received and accepted by it to ascertain the lowest evaluated Bid in conformity with the specifications of the tender documents.

The Technical Bids will be examined for minor matters regarding qualification of bids. Subsequent to correspondence with the respective bidders, the decision of Tender Committee will be final.

All responses to requests for clarifications shall be in writing and shall be presented to the Company through e-mail or in a sealed envelope on or before the given date requested by the Company. If the Technical clarifications sought by the Company do not reach the Company on or before due date, the Bid will be rejected.

The comparison of all the Bids shall be carried out with reference to the scope of work as per the technical specification. Any deviation/omission shall be evaluated at highest quoted price of the deviation/omission quoted by any of the Bidder. In case a separate price (for omission) is not given by any other Bidder, a reasonable price of the same shall be taken & the same shall be binding to the Bidders.

The commercial deviation, if any, shall be loaded to bring all the Bids at par. The loading shall be carried out at an interest rate of 2% above PLR of SBI.

A Bid to be substantially responsive shall be one which on evaluation confirms to all the terms, conditions and specifications of the Bid documents without any material deviation or reservation.

For the above referred purpose, a 'material deviation' shall be one which:

- (a) Which affects in any substantial way the scope, quality or performance of the contract, or
- (b) Which limits in any substantial way and in a manner inconsistent with the Bid documents, GIPCL's right or the Bidder's obligations, under the contract, or
- (c) Whose rectification would affect unfairly the competitive position of other Bidders presenting substantially responsive Bids.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

14. RIGHT OF REJECTION OF TENDERS

GIPCL reserves the right to accept or reject any Bid or to cancel the Bidding process and reject all Bids at any time prior to award of contract, without thereby incurring any liability to the affected Bidder or Bidders or any obligation to inform the affected Bidder or Bidders regarding the same.

Any Tender without EMD and Tender fee will be treated as non responsive and shall be rejected at the outset & no further correspondence shall be entertained regarding this.

GIPCL reserves the right to debar any Bidder from participation in future Bids if such Bidder has quoted an abnormally low rate in the Bid document/price Bid.

15. AWARD OF CONTRACT

GIPCL will award the contract to that bidder whose quotation has been determined to be substantially responsive and evaluated as the lowest quotation in conformity with the requirements of the specifications and documents contained herein, provided further that the bidder is determined and evaluated to be qualified to perform the contract satisfactorily.

The successful bidder shall be intimated of his selection through the Letter of Intent or Letter of Award/ Work Order which shall be sent to him through e-mail, courier, fax or registered mail.

GIPCL reserves the right to cancel / short close the contract during the contract period without assigning any reason. GIPCL has right to cancel / short close the contract at any time by giving him 15 days advance notice without assigning any reason and will make the alternate arrangement at the risk & cost of contractor.

GIPCL reserves the right to split the contract quantity between vendors.

16. CONTRACT PERIOD

- 16.1. The contract will be for a period of one years from the date of actual commencement of operation of the contract as stated in the Work Order ('**Contract Period**').
- 16.2. GIPCL reserves the right to extend the Contract Period for up to 3 months on the same terms and conditions without any price escalation and entering into any new contract.
- 16.3. The said Contract Period can be extended, if mutually agreed upon by both the parties up to one year and in such a case a revised work order shall be issued at the same rates and terms & condition or at negotiated rates acceptable by both parties i.e. the Company & the Contractor.

17. ASSIGNMENT AND SUB-LETTING

The Contractor shall not directly or indirectly assign or sub-let total/any part of the contract to any other party or agency.

18. CONTRACTOR'S OBLIGATIONS

A: DEPLOYMENT & RESPONSIBILITY OF MANPOWER

The Contractor shall deploy suitably qualified and sufficient manpower for timely & satisfactorily execution of the works under the contract.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

The Contractor shall deploy sufficient skilled, Semi-skilled and Un-skilled manpower like technician, Fitter, helper, rigger, welders, cutter, electrician, store keeper etc. for properly complete the job in given/scheduled time.

The Contractor shall depute workmen/labour with proper identification to enter the plant premises after ensuring that the jobs are scheduled.

At the time of deploying manpower, the Contractor shall strictly comply all the applicable labour laws/Acts norms including but not restricted to the age of the workers, women workers and shall also ensure that a police verification and security check for all the workmen/labour engaged at the GIPCL site is done and necessary documents regarding the same shall be submitted to the GIPCL's authorized representative/officer-in-charge. Any default in complying with the same or any misrepresentation regarding compliance of the same shall compel GIPCL to initiate appropriate civil or criminal proceedings regarding the same.

The Contractor shall also comply with the safety requirements and provide his workmen/labour with safety equipment like helmets, masks, gum boots, a uniform and other necessary PPEs for properly undertaking the operations involved under this contract. Following are also to be issued:

- a) Safety shoes
- b) Goggles / face shield.
- c) Ear plug / Ear muff.
- d) Hand gloves like electrical hand gloves / cotton hand gloves / Chemical hand gloves
- e) Boiler suits

Contractor shall nominate /authorise senior experienced person in writing as site in charge to co-ordinate with GIPCL engineer and who shall bear overall responsibility for performance of the contract. Such person shall remain always available at site or site office allotted to the contractor at SLPP site. Contractor has to submit the authority letter and documentary proof for the same.

The Contractor shall appoint a supervisor who shall co-ordinate with GIPCL's Engineer In - Charge for daily maintenance job. They have to maintain daily job register dully signed for the works carried out and duly certified by engineer in charge. The Contractor in co-ordination with the Engineer-In-Charge shall ensure the availability of adequate manpower to carry out the job satisfactorily on a daily basis. As per the instruction of engineer in charge they have to allot the work and execute the same in specified time limit.

During execution of the works, one or more jobs may be required to be done simultaneously and the Contractor shall mobilise additional resources accordingly.

Contractor has to carry out the work simultaneously at one or more locations. Accordingly, contractor shall mobilize resources.

During emergency or similar situations, the Contractor shall be required to mobilise resources as per need within the period of 24 hours as directed by GIPCL. If the contractor fails to mobilise sufficient manpower to complete the job in time, GIPCL will execute the job through other agency at the risk and cost of the contractor with 10% supervision charges & the same will be recovered from the Contractor's bill.

During working in high risk area like hot lines / duct of steam, air & flue gas / water/ oil / height the workman must wear a suitable safety apron, safety belt, safety hand gloves and goggles. It is the contractor's/contractor's supervisor's responsibility to ensure it without fail.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

During unit Shut down, overhauling, the contractor has to enhance the site manpower as per the requirement to ensure the timely completion of work (During overhauling period quantum of soot blower work increases substantially). For this, enhanced work shall be completed by deploying additional manpower with separate supervisor. Payment will be made on job rate basis only. The work during the overhauling period is to be carried out round the clock. Contractor should mobilise sufficient number of manpower and execute the work in two shifts with independent manpower. Contractor should not continue the same manpower more than 12 hours.

B: TOOLS & TACKLES

All tools and tackles to execute the contract are in the scope of the contractor. The contractor should ensure that tools are in healthy condition. All consumable items i.e. cloth, cotton waste, kerosene oil, gases (Oxygen, D/A, Argon), welding machine, lifting tools, winch machine / Lifting arrangements, grinding machine, cutter machine, welding electrode, wire brushes, Water and air flexible hose with connectors, lighting equipment, etc. would be in the scope of the contractor.

All tools and tackles required to execute the contract are in the scope of the contractor. The contractor should ensure that tools and tackles are in healthy & working condition.

All consumable items would be in the scope of the contractor.

Note: If work is suffered due to want of sufficient manpower, tools & tackles, vehicles, equipment and/or required consumables then 10% of the total job cost will be levied as a penalty for each and every instance

For proper execution of the work as per the scope, the contractor is required to maintain sufficient quantity of tools & tackles in good working condition at site as per day to day work load and emergency situations to complete the work in stipulated time.

In case of breakdown of equipment, the contractor should work round the clock for putting back the area in service immediately within minimum time. In case of any emergency arising during night hours the contractor should be in a position to mobilize the manpower immediately within minimum time.

Arrangements for lighting at the work spot has to be made by the contractor. He has to arrange all lighting equipment such as power cable, hand lamps. The contractor has to take prior approval for taking electrical power supply. The contractor should keep hand lamps of 24Volt for confined space and sufficient quantity of 240 Volt and halogen lamp for other area ensuring safety at work place.

Pin sockets of IS standards should be used for all connections. For any accident take place & any damage to the equipment and/or injury to human due to carelessness in loose connection, contractors will be held responsible & liable for any recovery/actions.

Scrap materials should be collected in separately with proper care and then disposed at a suitable location as per the instruction of engineer in charge. It is the responsibility of site in charge to segregate and remove the scrap from site. Work will be certified by E-I/C only after removal of scrap to the scrap yard.

If any equipment or part are found damaged due to negligence / fault of contractor, the cost of such damages shall be recovered from the contractor bill.

Contractor shall nominate / authorize a person in writing as Site in charge to coordinate with GIPCL engineer and should bear overall responsibility of contract. Such person shall function from site office of contractor at SLPP. Adequate Supervisory staff for execution of said work should be deployed round the clock.

The decision of the Engineer in charge shall be final and binding on the contractor for defining the terms and condition included in this contract.

Inspection of work will be done by engineer in charge or his authorized representative, if the work is not found satisfactory, engineers in charge reserves the right to take suitable action.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

The contractor has to do quality job. GIPCL shall not compromise in quality. In case of poor quality of work the contractor may be asked to rework the job.

Contractor has to carry out the work simultaneously at one or more locations. Accordingly, contractor shall mobilize resources.

19. CLARIFICATION OF BIDDING DOCUMENTS

If any Bidder requires any further information or clarification in the Bidding Documents, may notify the Company before one week of last date of submission of online Bid, in writing or by E-mail at the GIPCL's mailing address bggajjar@gipcl.com as indicated in the 'Invitation to Bids'. The GIPCL's response (including an explanation of the query) will be sent in writing or by E-mail to all prospective Bidders who have received the Bidding Documents.

20. TIME SCHEDULE

The basic considerations and the essence of the 'Contract' shall be the strict adherence to the time schedule for performing the specified 'Works'. Contractor has to complete the each activity as per time schedule given by the E-I-C.

- **Contract period:** one years from the date of actual commencement of operation of the contract as stated in the Work Order.
- **Time schedule for completion of job is as below:**
 - Party shall be in position to mobilise sufficient resources and tools & tackles so that work can be completed in time bound period in the Units in parallel without causing any delay.
 - The contractor has to deploy separate groups for working parallel in different area of boilers as per instruction of Engineer In-charge.
 - The basic considerations and the essence of the 'Contract' shall be the strict adherence to the time schedule for performing the specified 'Works'. The entire works as specified in scope of work shall be completed as above.
 - The work shall be carried out continuously round the clock as per plant requirements **in Running unit, annual overhauling and other shutdown works**. Separate gangs shall be engaged in each shift without engaging the same manpower in annual overhauling and forced shutdown work to complete the Soot Blower work within stipulated time provided by GIPCL EIC.
 - During unit running condition, party has to attend maximum possible area of soot blower work as per instruction of EIC.
 - In case of delay in executing the contract by contractor, GIPCL will execute the job through other agency at the risk and cost of the contractor with 10% supervision charges & the same will be recovered from the Contractor's bill.
 - The work shall be carried out continuously round the clock with **2x12 hours shift working in AOH works of Two units**. Separate gangs shall be engaged in each shift without engaging the same manpower in annual overhauling and forced shutdown work to complete the Inspection and servicing of Long Retractable soot blower & half retractable soot blowers within stipulated time provided by GIPCL EIC.
 - AOH of Boiler units planned from the month of **May - 2025 to December - 2025**. Tentatively AOH of Unit # 3 is planned in the month of June – 2025 and AOH of Unit # 2 is planned in July – 2025. However actual schedule of AOH as well as unit may change as per plant requirements.
 - In case of delay in executing the contract by contractor, GIPCL reserves the right to engage another contractor and complete the balance job at the risk and cost of the contractor.
 - Payment shall be made as per actual quantity of work execution.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Time Schedule for Part A & B:

- The entire works of soot blowers of boiler during AOH as specified in scope of work shall be completed within 20 days for each unit from the date of hand over of front from GIPCL.

Time Schedule for Part C:

- Inspection for checking healthiness of all soot blowers & servicing of selected soot blowers of Unit 1,2,3 & 4 shall be at least 07 days at site after intimation from GIPCL as and when required.

The Contractor shall be required to shift spares, material etc in required quantity duly approved by GIPCL's Engineer-in-Charge whenever necessary from GIPCL store/ warehouse to site or site store as per the instructions of Engineer- in -charge. Contractor shall be required to arrange transportation for above. The cost of transportation will be on contractor's account. The contractor shall be responsible for safe transportation, handling and storage. If equipment fails due to improper material or intermixing the cost of such damages shall be recovered from contractor's bills. It is the responsibility of contractor to keep various materials separately to avoid intermixing. The failure /defects of equipment due to improper method of work, equipment assembly due to contractor negligence, and the losses will be recovered from contractor's bills.

Arrangement for lighting at the work spot has to be made by the contractor. He has to arrange all lighting equipment such as power cable, hand lamps. The contractor has to take prior approval for taking electrical power supply. The contractor should keep hand lamps of 24Volt, 240 Volt and sufficient quantity of halogen lamp.

Electrician/supervisor should ensure that the cable connection is not in loose condition, which may cause any damage or failure to the machine/manpower. Pin sockets of IS standards should be used for all connections.

The Contractor must ensure that all the generated scrap are removed from the site immediately and he must ensure cleaning of the site. Further, these items should be disposed off to the scrap yard or any other designated place as instructed by Engineer In Charge. In case of heavy weight items, if required transportation may be arranged by the GIPCL at the discretion of the engineer in charge on chargeable basis. If the scrap removal is not done within the stipulated time given by GIPCL Engineer, the scrap will be removed by GIPCL at the Contractor's cost with penalty and it will be deducted in the bill.

Scrape materials should be collected in separately with proper care and then disposed at a suitable location as per the instruction of engineer in charge.

It is the responsibility of site in charge to segregate and remove the scrap from site. Work will be certified by E-I/C only after removal of scrap to the scrap yard.

If any equipment or part are found damaged due to negligence / fault of contractor, the cost of such damages shall be recovered from the contractor bill.

Contractor shall nominate / authorize a person in writing as Site in charge to coordinate with GIPCL engineer and should bear overall responsibility of contract. Such person shall function from site office of contractor at SLPP. Adequate Supervisory staff for execution of said work should be deployed round the clock.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

The decision of the Engineer in charge shall be final and binding on the contractor for defining the terms and condition included in this contract.

Inspection of work will be done by engineer in charge or his authorized representative, if the work is not found satisfactory, engineers in charge reserves the right to take suitable action.

The contractor has to do quality job. GIPCL shall not compromise in quality. In case of poor quality of work the contractor may be asked to rework the job.

Contractor has to carry out the work simultaneously at one or more locations. Accordingly contractor shall mobilize resources.

21. UNDERSTANDING AND CLARIFICATION ON DOCUMENTS AND SPECIFICATION

The Bidder is required to carefully examine the specifications and documents, all the conditions and matters work wise & cost wise. If any Bidder finds any discrepancies or omissions in the specifications and documents or is in doubt for any meaning of any part, he shall request in writing for an interpretation/ clarification to the GIPCL.

All such interpretations and clarifications shall form a part of the Bid documents.

22. PAYMENTS

All the payments against the work order shall be in Indian currency and payable through cheque/RTGS only.

23. POINTS TO BE CONSIDERED DURING QUOTING ONLINE PRICE BID:-

- a. The schedule of rates shall be read in conjunction with Instructions to Bidders, General conditions of contract, Special conditions of contract and Technical specifications.
- b. The quantities given in the schedule of rates are estimated and payment will be made as per actual work carried out as per the rates of work order.
- c. The method of measurement of completed work for payment shall be in accordance with actual measurement.
- d. No separate amount shall be payable for use of auxiliary equipment incidental to or in day to day operation in the course of fulfilment of contractual obligation of the vendor.

Note: Interested bidders are requested to submit the online tender at least two days in advance from the due date set for on line submission of bid in order to avoid non-participation of e-tender due to probable technical problem in e-tender system.

24. QUANTITIES

The quantities specified are estimated and for tendering purpose only. Payment will be made, based on actual work done as certified by Engineer-in-charge of GIPCL.

Quantities of individual items may be revised during the course of contract period based on site requirement. Contractor shall not be entitled for any compensation on ground of such alteration in scope of work. GIPCL reserves the right to operate or increase/decrease quantities in each item or omit any item included in Schedule of Quantity at his discretion. Contractor shall have no claim, whatsoever, on grounds of loss of anticipated profit etc. on account of the same.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

After commencement of the work, GIPCL, for any reason may not require to be carried out the whole/part of the work as specified in the tender, the ENGINEER-in-charge shall inform the fact for thereof to the CONTRACTOR and contractor shall have no claim for any payment or compensation whatsoever on account of any profit or advantage which he might have derived from the execution of the work in full but which he did not derive in consequence of the full amount of the work not having been carried out nor shall he have any claim for compensation by reason of any change having been made in the original specifications and instructions which shall involve any curtailment of the work as originally contemplated.(to be reviewed with legal and to be incorporated in special conditions only)

SECTION-B

INSTRUCTIONS TO BIDDERS FOR ONLINE TENDERING

- Tender document is available only in electronic format. Bidders can download free of cost from the GIPCL e tender portal (<http://etender.gipcl.com>), and It can also be viewed from Company's website www.gipcl.com .
- All Bids Pre-Qualification / Techno-commercial bid (Part-1) and Price Bid (Part-2) shall be submitted Online through the GIPCL's E-Tender portal: <https://etender.gipcl.com/>. The Part-1 of Bid may be submitted in Physical form, but (Part-2) shall be submitted **online only**. Physical submission of Price Bid will not be entertained. Also no fax, e-mail, letters will be entertained for the same.
- Following should be submitted 'off-line' in sealed covers separately during dates & time set in 'NIT' at our Office at Village: Nani Naroli, Taluka: Mangrol, Dist.: Surat - 394 110, Gujarat:
 1. Tender Fee,
 2. E.M.D.,
 3. Supporting Documents for Technical Bid
- Bidders who wish to participate first time in Online tenders will have to register their firm at GIPCL-SLPP by applying for registration through 'Vendor registration option' available in the website - <https://etender.gipcl.com/> at least before five (7) working days from the due date set for Online Bid participation. GIPCL will not be held responsible in case of late submission for Vendor registration. Bidders shall fill the online vendor registration form and submit it online. GIPCL will create 'Vendor Code' which will be used as user ID for online participation in GIPCL's tenders. Both vendor code (user ID) and password will be generated automatically and will be sent by auto generated e-mail to Bidder's official e-mail account as provided by Bidder in vendor registration form.

SECTION-C

GENERAL CONDITIONS OF CONTRACT

1. CONTRACT SECURITY DEPOSIT/ PERFORMANCE BANK GUARANTEE:

As a Contract Security/Performance Bank Guarantee, the successful Bidder, to whom the work is awarded, shall be required to furnish a Performance Bank Guarantee (PBG)/Contract security deposit (SD) in favour of Gujarat Industries Power Company Limited of an equivalent amount of ten percent (**10%**) of the " Annual Contract Price excluding taxes and duties" from any Schedule Public Sector Bank or Schedule Private Sector Bank in the format attached in **SECTION-F**, and it shall guarantee the faithful performance of the 'Contract' in accordance with the terms and conditions specified in these documents and specifications. Contract security deposit/PBG shall be submitted strictly within twenty-one days from the date of LOI or work order, whichever is earlier. The PBG/ Security Deposit shall be valid up to retention period of four months from the contract completion date, and claim period of three months from the completion of claim period. The Guarantee amount shall be payable to the Company in Bidder's home currency without any condition whatsoever.

GIPCL reserves the right to forfeit Performance Bank Guarantee (PBG)/Contract security deposit.

The Performance Bank Guarantee (initial security deposit) will be returned to the Vendor/Contractor without any interest at the end of the 'Retention Period' after completion of contract and on fulfilling contractual obligations throughout the retention period. However, any delay in submission of SD will result in equivalent late release of entire SD after guarantee period.

Bid security/EMD shall be refunded to the successful bidder on receipt of Performance Security.

2. RECOVERY CLAUSE

- (i) In case of any damage of equipment/machinery due to negligence of contractor or any other reasons attributed to contractor the decision of Engineer-in-charge regarding the amount of recovery shall be final and binding subject to a maximum of **10%** of contract value. Recovery will be affected from the monthly bills and/or retention money/security deposit.
- (ii) If the contractor fails to execute the work as per directions of Engineer (I/c) within the time frame given in work order and as per day to day instructions by Engineer-in-charge, GIPCL shall get the work done by third party at the risk & cost of the contractor with **10%** additional overhead charges of GIPCL.

3. DEDUCTIONS FROM CONTRACT PRICE

All costs, charges or expenses that GIPCL may have paid, for which, under the contract the contractor is liable, shall be recovered by the GIPCL. The contractor shall pay all such claims within **15 days** of claim failing which the same shall be deducted from the bills of contractor.

4. TERMINATION OF CONTRACT BY GIPCL

Contractor shall be responsible to complete the jobs within agreed time schedule and in case contractor fail to complete the job, GIPCL shall recover from his bill, Security Deposit and / or whatsoever for expenses incurred to complete the job with additional **10%** overhead charges.

In case if contractor's services are not found satisfactory with respect to mobilization, time bound completion of work, workmanship & safety (OHSAS policy of GIPCL) then GIPCL has right to "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

terminate the contract at any time by giving him **15 days** advance notice without assigning any reason and will make the alternate arrangement at the risk & cost of contractor.

GIPCL may terminate the contract after due recoveries of pending jobs/damages after giving 15 days advance notice to the contractor if any of the following events occur –

- I. Contractor is adjudged as insolvent.
- II. Contractor has abandoned the contract.
- III. Contractor fails to proceed with the work with due diligence as per requirements of the contract.
- IV. Contractor has neglected or failed persistently to observe or perform any of the acts, matters or things, which as per the contract are to be observed and performed by the contractor.
- V. Contractor repetitively violating the safety norms for more than three incidents.
- VI. Any major contradiction of applicable labour laws.
- VII. Any major deviations from contractual terms and conditions including quality of job.
- VIII. GIPCL reserves the right to terminate the contract without giving any reason whatsoever and forfeit the PBG.

5. FAILURE & TERMINATION

If the CONTRACTOR after receipt of written notice from the GIPCL/ ENGINEER requiring compliance, with such further drawings and / or the GIPCL /ENGINEER instructions fails within seven days to comply with the same, the GIPCL /ENGINEER may employ and pay other agencies to execute any such work whatsoever as may be necessary to give effect thereto and all costs incurred in connection therewith shall be recoverable from the CONTRACTOR by the GIPCL on a certificate by the GIPCL/ENGINEER as a debt or may be deducted by him from any money due or to become due to the CONTRACTOR.

If the contractor fails to execute the work or fails to mobilize the resources and equipments as per directions of GIPCL / ENGINEER within the time frame given and/or violating the GIPCL's safety rules & regulations, ENGINEER/ GIPCL shall get the work done by third party at the risk & cost of the CONTRACTOR with additional 10% overhead charges of GIPCL and all costs incurred in connection therewith shall be recoverable from the CONTRACTOR by the GIPCL /ENGINEER as a debt or may be deducted by him from any money due or to become due to the CONTRACTOR.

6. SETTLEMENT OF DISPUTES

- a) Any disputes or difference of opinion between parties arising out of the contract to the extent possible shall be settled amicably between the parties. If amicable settlement cannot be reached all the disputed issues shall be resolved through arbitration before a Sole Arbitrator appointed by Managing Director, GIPCL according to the provisions of The Arbitration & Conciliation Amendment Act-2019, as amended from time to time. The place of arbitration shall be at Vadodara/ Surat or any other place within state of Gujarat.
- b) Work under the contract shall be continued by the contractor during arbitration proceedings unless GIPCL shall order suspension thereof or any part thereof in writing or unless the matter in such work cannot possibly be continued unless the decision of the Arbitration proceedings is obtained.

7. INTERPRETATION OF CLAUSE

In case of disputes as regards interpretation of any of the clauses or specification, the decision of Head of Management (HOM)-GIPCL will be final and binding on the contractor.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

8. EMPLOYEE'S COMPENSATION INSURANCE

Contractor shall take all risk Insurance Policy to cover all his workmen/employees, staff applicable under the Employee Compensation Act 1923 or any amendment thereof as also insurance cover for third party liability. The contractor shall keep the GIPCL indemnified from all liabilities arising out of his action in pursuance of this contract. The E. C. Policy should be obtained from Baroda/Surat Jurisdiction (As per Work Location) and shall be assigned to GIPCL. EC policy should cover the specified contract period.

Contractor shall also obtain additional off-duty coverage insurance policy for all his workers.

9. STATUTORY REQUIREMENTS

The contractor shall be solely responsible for any accident caused to his workers and should adhere to all rules / regulations as per labour laws of Government and other statutory laws as applicable.

The contractor should register himself under the Contract Labour Act, Employee Compensation Act and PF Act (Code no. to be mentioned) and submit the copy of registration certificate and should possess the same from the date of commencement of work, failing which the contract is liable to be cancelled. The E.C. Policy copy should be submitted to the GIPCL before commencement of the work and Labour License should be obtained within one week from the date of issue of form-V. Contractor should apply for Form-V immediately after receipt of LOI. A copy of Labour License shall be submitted to GIPCL, HR & A Department.

Contractor shall have to insure his workmen /supervisors etc. under Group Insurance scheme.

The Contractor shall be responsible for compliance of all statutory rules, regulation, act enforced from time framed by the government such as Factory Act, Employee Compensation Act, payment of 'Wages Act', Minimum Wages Act', Provident Fund Act, All Labour Laws Act in respect of employees engaged by him for the work and shall have to maintain necessary records. In case any amount becomes due to be payable by him to his employees or to the Government under the above rules, regulation, Acts, GIPCL reserves the right to recover the same from the running bill of the contract. Documentary evidence of deposit of PF paid shall have to be produced by the contractor along with the next bill.

Records as per the provisions of various statutory Acts will have to be maintained by the contractor and submitted as and when required.

All employees of contractor should maintain due discipline and respect local sentiments. GIPCL reserves the right to direct the contractor to remove any such person who does not comply with it.

a. COMPLIANCE OF LABOUR LAWS

The contractor shall at his own cost comply with the provision of labor laws, rules, orders and notifications whether central or state or local as applicable to him or to this contract from time to time. These Acts/Rules include without limitation of the followings.

1. Contractor shall be solely responsible and shall fully comply with all the provisions of all the labor laws applicable such as the Minimum Wages Act, 1948, Contract Labor (Regulation & Abolition) Act 1970, Factories Act, 1948, Payment of Bonus Act 1965, Employees Provident Fund and Miscellaneous Provision Act 1952, Industrial Dispute Act 1947, Workmen Compensation Act 1923, Payment of Gratuity 1972, Interstate Migrant Workmen Act 1979,

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- Equal Remuneration Act with Rules, Order and Notifications issued/made there under from time to time.
2. All other Acts, Rules/Bye-Laws, Orders, Notifications etc. present of future applicable to the contractor from time to time for performing the contract job.
 - 2.1 The Contractor shall provide and be responsible for payment of Wages, Salaries, Bonus, Social charges, Insurance, Food, Accommodation, Transport, Medical and Canteen facilities and other statutory privileges and facilities to his personnel as per law/rules/regulations and orders of the Central Government, State Government, Local Authorities or other authorities as are in force from time to time. All employees of the Contractor shall be employee of the Contractor.
 - 2.2 The contractor shall have a valid license obtained from Licensing Authority under the Contract Labor (Regulation & Abolition) Act-1970 at the time of execution of the contract covering all his employees working at SLPP site and furnish the same failing which GIPCL may terminate the contract at its sole discretion.
 - 2.3 The Contractor shall at the time of execution of the contract have a EPF Code Number obtained from the Authorities concerned under the Employees Provident & Miscellaneous Provisions Act, 1972 and remit contributions in respect of the employees employed by him at SLPP Site to the P.F office concerned every month failing which GIPCL will recover from the outstanding payment to the contractor from GIPCL.PF code of Gujarat region should be taken.
 - 2.4 The Contractor shall maintain all records/registers required to be maintained by him under various labor laws mentioned above and produce the same before the Statutory Authorities whenever required.
 - 2.5 The Contractor shall also submit periodical reports / returns to the various statutory authorities such as the Contract Labour (Regulation & Abolition) Act-1970, Employees Provident Fund Act etc. Under intimation to HR&Admn.Dept.
 - 2.6 The Contractor shall not pay less than the Minimum Wages notified by the Government from time to time to his employees of corresponding categories.
 - 2.7 The Contractor shall be responsible for payment of overtime wages to his workmen, if any, in case they are required to work beyond the prescribed hours under law as per applicable rates.
 - 2.8 The contractor shall take Workmen Compensation Insurance Policy for all his employees working at GIPCL. The contractor shall indemnify the company against any liability due to any work injury or accident to any of its employees.
 - 2.9 The Contractor shall in the event any of his workmen / employee sustains any injury or disablement due to an accident arising out of and in the course of his employment, provide necessary medical treatment and pay compensation as applicable, required under the Workmen's Compensation Act, 1923.
 - 2.10 If any of the persons engaged by the Contractor misbehave with any of the officials or the Company or commit any misconduct with regard to the property of the Company or suffer from any serious communicable disease, the Contractor shall replace them immediately.
 - 2.11 The Contractor shall not engage / employ persons below the age of 18 years. Employment of women shall be strictly according to applicable laws.
 - 2.12 GIPCL will have right to deduct and disburse the claims of the individual / parties being a principal employer on any account whatsoever in relation to their employment with the contractor. The Security deposit will be released to the contractor at the end of the contractual tenure subject to an undertaking by the contractor that in the event any of his workmen or the heirs of workmen puts up a claim for recovery of money due to him from the contractor before the appropriate authority under the I.D.Act 1947 or under any other labor laws or for compensation under the Workmen's Compensation Act, 1923 and the appropriate authority has given a direction for making payment the contractor will meet the same or indemnify GIPCL if in the event GIPCL pays it as Principal Employer.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- 2.13 The contractor shall make payment of wages to his employees on fixed date within the period specified under the applicable Law, in presence of representative of the company. He will submit a true copy of wage sheet, attendance register and P.F. remitted challan on monthly basis to HR&A dept. for verification and record.
- 2.14 The Contractor shall provide Safety items / kits to his employees such as safety shoes, goggles, ear plugs, hand gloves, safety belts etc., if any, required under the law.
- 2.15 The contractor shall conduct pre-induction and periodic medical checkup of his workmen as per applicable laws.
- 2.16 The contractor shall be solely responsible for any accident caused to his workers and should adhere to all rules / regulations as per labor laws of Government and other statutory laws as applicable.
- 2.17 The contractor should register himself under the Contract Labor Act, Employee Compensation Act and PF Act (Code no. to be mentioned) and submit the copy of registration certificate and should possess the same from the date of commencement of work, failing which the contract is liable to be cancelled. The E.C. Policy copy should be submitted to the GIPCL before commencement of the work and Labor License should be obtained within one week from the date of issue of form-V. Contractor should apply for Form-V immediately after receipt of LOI. A copy of Labour License shall be submitted to GIPCL, HR & A Department.
- 2.18 Contractor shall have to insure his workmen /supervisors etc. under Group Insurance scheme.
- 2.19 The Contractor shall be responsible for compliance of all statutory rules, regulation, act enforced from time framed by the government such as Factory Act, Employee Compensation Act, payment of 'Wages Act', Minimum Wages Act', Provident Fund Act, All Labor Laws Act in respect of employees engaged by him for the work and shall have to maintain necessary records. In case any amount becomes due to be payable by him to his employees or to the Government under the above rules, regulation, Acts, GIPCL reserves the right to recover the same from the running bill of the contract.
- 2.20 Documentary evidence of deposit of PF paid shall have to be produced by the contractor along with the next bill.
- 2.21 Records as per the provisions of various statutory Acts will have to be maintained by the contractor and submitted as and when required.
- 2.22 All employees of contractor should maintain due discipline and respect local sentiments. GIPCL reserves the right to direct the contractor to remove any such person who does not comply with it.
- 2.23 The list is indicative in nature and not an exhaustive one. Any amendment/alteration/Notifications or addition to the existing Law or a new statute shall automatically and immediately become applicable.
- 2.24 Annual Health Check Up: - As per statutory requirement, Contractor has to inform workmen deployed at site for annual health checkup as per schedule prepared by HR&A department.

b. LEGAL ASPECTS

1. Contractor shall maintain all registers required under the Labour Laws and make the payment as per the Minimum Wages Act to the workers employed by him.
2. Contractor shall obtain requisite license to carry out this contract under the provisions of Contract Labour Act, 1970 and maintain necessary records and registers under the said Act.
3. Contractor shall submit a copy of each of the registration certificates with respect to Employees Provident Fund and Employee Compensation Act within one-week time, from the date of award of this contract.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

4. Contractor's employees, agent or sub-agent shall not smoke or light anything within the premises of the GIPCL and carry match box / lighter or any other explosive and /or inflammable material inside the plant.
5. Contractor shall abide by all the statutory rules and regulations like P.F, Labour Laws etc.
6. Contractor shall issue an appointment order to each casual labourer stating therein the nature of job shall be performed by him and fix time for which the concerned labourers are likely to be deployed. Contractor shall also issue a temporary identity card specifying the period for which the labourer has been deployed.
7. Contractor is fully liable for the persons engaged by him for above work; however, GIPCL reserves the right to deduct any amount legally justified towards any liability not fulfilled.
8. Contractor shall indemnify GIPCL from any liabilities arising out of the employment of the manpower.
9. If the contractor fails to complete the allocated job within specified time frame, GIPCL shall get the work done by third party at the risk and cost of contractor.

10. PAYMENT OF WAGES

Contractor shall be responsible for compliance of all statutory rules, regulation, act enforced from time framed by the government such as Factory Act, Employee Compensation Act, payment of 'Wages Act', Minimum Wages Act', Provident Fund Act, Payment of Bonus Act, Labor Law Act, maternity benefit act in respect of employees engaged by him for the work and shall have to maintain necessary records. In case any amount becomes due to be payable by him to his employees or to the Government under the above rules, regulation, Acts.

11. ACCIDENT TO WORKMEN

Contractor shall be fully responsible for injury or death of any of your or third-party workmen due to any act omission / indiscretion on your part while undertaking the work and contractor shall fully abide by the statutory requirements of the employee's compensation act. GIPCL shall not be liable for any compensation due to accident, death or injury to any of contractor's workmen or any third party due to negligence, act or omission on your part.

12. LIGHTING

Arrangement for lighting at the work spot has to be made by the contractor. He has to arrange all lighting equipment such as power cable, hand lamps. The contractor has to take prior approval for taking electrical power supply. The contractor should keep hand lamps of 24Volt for confined space and sufficient quantity of 240 Volt and halogen lamp. for other area ensuring safety at work place

Electrician/supervisor should ensure that the cable connection is not in loose condition, which may cause any damage or failure to the machine/manpower. Pin sockets of IS standards should be used for all connections. For any accident take place & any damage to the equipment and/or injury to human due to carelessness in loose connection, contractors will be held responsible & liable for any recovery/actions.

13. NIGHT/SUNDAY/HOLIDAY SHIFT

The contractor shall depute qualified and adequate resources in night shift/Sunday/holidays for any emergency job, which may come up at night/Sunday/holiday.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

14. SAFETY ASPECT

Contractor shall observe all the safety and security rules and regulation of the GIPCL which are at present in force and which may come into force during the pendency of the contract. Any violation of any rules and regulations will entail immediate termination of the contract.

When contractor moves his lifting tools and tackles to the plant area, required test certificates as per the Factory Act 1948 and the state factories rules has to be submitted to safety Deptt. Safety Dept. will check the certificates and if found okay, then only materials will be allowed to enter inside the plant. Material inward gate pass will be made only after certification from Safety Dept. Security Dept. will inform to Safety Dept., as & when such tools and tackles brought at the gate for making entry in the maintenance site.

The contractor has to submit the list of required safety gears along with safety equipment available with him to safety Dept. Safety Dept will check for quantity and quality of the safety gears and then allowed permission of work. Poor quality material will not be allowed to take inside the Plant. If quantity of required safety equipment is not satisfactory, contractor will not be allowed to carry out the work using such safety gears inside the Plant for the work.

15. GENERAL SAFETY CLAUSES:

1. The Contractor shall observe and comply, with regard to his workmen working at the SLPP site, the safety norms as per the safety operating standards.
2. The Contractor shall ensure that his workmen are informed and trained regarding the safety standards to be adopted while operating within the SLPP Plant & Mines premises and the Contractor shall brief them regarding the same and use of the Personal Protective Equipment ('PPE').
3. The Contractor shall issue safety shoes and safety helmet of IS standard to all his workmen immediately on execution of the work and the contractor shall ensure that his workmen wears the protective equipment at all times during the work operation. Contractor shall issue safety shoes every year Brand name for safety shoe & safety helmet shall be suggested by safety representative of SLPP site. Such as

Helmet :

Sr. No.	Model	Company	Specifications
01.	Tough Hat, HP-TH	Sure Safety	IS : 2925 – 1984, ANSI / ISEA Z89.1-2009
02.	V-Gard	MSA	
03.	PN 521 - helmet	Karam	

Safety shoes:

Sr No.	Model	Company	Specifications
01.	Acme Fabrik plast Co.	SSTEELE (Strom) – Double Density	IS : 15298 – 2011
02.	Acme Fabrik plast Co.	TRIMAX(Adjacent) – Double Density	
03.	Worktoes Warren	Worktoes - Warren Plus	

4. Other safety gears like ear plug, dust mask, hand gloves, safety goggles, gum boots, full body safety uniform and belts, safety net etc. shall be issued and used as per the job requirements. Safety helmet shall be of YELLOW COLOUR ONLY. Contractor will procure safety shoes & safety helmet from a reputed company with at least 12 months' guarantee and shall produce the guarantee certificate and IS standard certificate to the safety "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

department. Contractor should purchase safety shoes of reputed brands. Safety shoes will be issued every year. IS certificate and guarantee certificate must be obtained from the vendor and submitted to the Safety department. Safety shoes should be heat, water, oil and chemical resistant, having an anti-slippery sole of 15298- 2002 make.

5. It is the duty of contractor to ensure that his workmen are wearing required PPEs as per work requirement. Contractor should ensure that their workers are wearing Safety helmet, safety shoes, dust mask, goggles, ear plug etc. at all times when they are at work throughout the contract period. The contractor has to maintain the PPE issue registers with signature of workmen.
6. Contractor will reissue these PPEs in case of damage or misplacement of the same. Replacement shall be made immediately.
7. The contractor shall be responsible for providing first aid or emergency medical help and treatment to his workmen in the event of any accident or injury.
8. If it is observed that contractor is not issuing required PPEs timely and that of required quality, GIPCL will issue the required PPEs to contract workers and back charge the same with 25% overhead charges of GIPCL.
9. All lifting tools and tackles shall be duly certified by competent person in conformity with the statutory requirements and certificate in form no. 10 as per rule 60 of Gujarat Factories Rules, 1963 and section 29 of the Factories Act, 1948 shall be submitted every year before using such tools and tackles. In case of purchase of new lifting tools and tackles, form no. 10 as per the said rules shall be submitted before they are taken into use. All lifting tools and tackles shall be of reputed make having International manufacturing standard and shall be maintained in proper and workable condition.
10. The Contractor shall nominate one Safety Officer with required qualification for supervising the daily job/ shutdown jobs for observing and maintaining the safety aspects at site. He is solely responsible for any safety measures during maintenance work. He has to ensure that all the workmen working at site are equipped with essential PPE's and proper safety arrangement is made at the SLPP site.
11. After mobilization of any tools & tackles to site, which includes chain pulley blocks, D-shackles, wire ropes, winch machines, Mobile crane, Hydra etc. shall be offered for inspection with all above statutory test certificate before using at site for any work. They should use all tools and tackles only after certification by GIPCL representative/safety officer.
12. When working at height, working on ceiling or roof covered with fragile materials, full body harness safety belt, ladders and crawling boards shall be used to prevent accident. Further, during working on height, contractor should arrange proper scaffolding of still pipes, safety net, full body safety belt, fall arrestor system etc. Advice and instructions of engineer in charge/ safety in charge shall be strictly complied with in this regard. All necessary safety precautions shall be taken by the contractor to prevent accident and personnel injuries while working on height.
13. Flash back arrestors made of reputed manufacturer shall be provided on cutting torch, on DA cylinders and on O2 cylinder. Cylinder caps also required for handling the cylinders at the work at height area. Gas cylinders shall be transferred through gas cylinder trolley only with cylinder cap and stored up right (vertical) position only. All gas cylinders shall be hydro tested / certified as per gas cylinder rules 2004. Gas cylinders shall be stored, handled as per gas cylinder rules 2004.
14. All vehicles shall be operated by licensed drivers only. All vehicles' PUC to be tested as per Government approved RTO guidelines. All Vehicles must be parked in Parking space designated by GIPCL. If any vehicle is found inside the plant premises other than the parking area such vehicles shall be handed over to Security dept. and their entry shall be cancelled for movement inside the plant premises with immediate effect.
15. All electrical equipment shall be in good condition and free from any defect. Electrical tools & equipment i.e. welding machine, grinding and drill machine etc. may be checked by the "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

electrical engineer of the contractors regularly, every six month at least and report shall be submitted to concerned HOD and safety depts.

16. During hot work, contractor will use fire curtains like asbestos sheets or fire blankets to prevent falling and spreading of sparks and hot material on and around the work area. Contractor will procure and use such items. ELCB / RCCB shall be provided with rating of 9 - 30 milli amperes on welding machine and all portable power tools.
17. The contractor shall fill – up Incident notification form (S-I), Incident Investigation form (S-II) and near miss report within time limit as specified in forms, if any accident, Incident, near miss occurred while working at SLPP site.
18. Major AMC / ARC contractor (Where the man power strength is more than 50 and above) should appoint / nominate one qualified safety officer and he shall be responsible for addressing all the safety related aspects of execution of contract jobs and he will in close coordination with safety officer of SLPP and attend all safety related meeting such as safety committee, on job safety training etc. Where the contractual man power is less than 50, the site in-charge of the contractor will act as a safety officer and he will perform all the duties of safety officer as mentioned above.
19. No loose connection / joints allowed in electrical cables during performance of any kind of job.
20. Safety shoes shall be issued to female employees also.
21. All the vehicles shall be fit as per RTO guidelines and valid fitness certificate is required as per RTO guidelines.
22. The Contractor’s nominated safety officer shall be imparted regular on-job safety training like tool-box talk etc. and submit a record of such training in safety dept, respective dept and HR&A dept.
23. The Contractor shall comply all the new requirements related with safety as informed by the HOD / Safety department from time to time.
24. Penalty shall be imposed for Violation of safety norms is proposed as follows:- The Contractor & Contract workmen shall strictly adhere to Safety standards / Guidelines as per practices. The list provided below is an indicative list to explain the principles behind safety practice. If the contract workmen fail to comply with safety standards as per category A, B & C below, penalty shall be levied on the contractor as per the table mentioned below:

Category	Classification	Examples / Cases	Penalty
A	PPEs Related	Working without helmet, shoes, safety belt, gloves etc.	Rs. 100/- per instant.

B	Work Instruction Related	Failure to adhere to HSE guidelines/plans, careless attitude in material handling, Machine being used with damaged machine guard, unsafe electrical work – workout plug top/improper electrical joints/cables lying on ground, electrical equipment working without proper earthing, machine being used without machine guard, Welding machine without incidence ELCB / RCCB of proper rating, Gas cylinder without test certificate, Cylinder cap, NRV /Flash back arrester, Cylinder trolley etc.	<ul style="list-style-type: none"> Rs. 500/- per instant After three incidence. Per incidence Rs. 2500/-. Continuous unsafe acts will disqualify the contractor from further participation in tender of GIPCL-SLPP.
		Unsafe working practices at height more than 3 Meters.	
		Working without permit non-compliance with permit conditions like hot work, height work etc. as applicable, lifting tools and tackles being used without third party inspection certificates in form no. 9/ 10 as per Factory Act - 1948 etc.	
C	Unsafe Practices	Breach of safe practices by a particular person repeatedly for three times.	<ul style="list-style-type: none"> Suspend the entry gate pass for one week. <ul style="list-style-type: none"> After two suspensions his gat pass will be cancelled

Penalty so levied against the contractors and company employees will be used during the observation of National Safety Day.

The contractor, workmen following good safety practices in their work area continuously will be rewarded / honored on National safety day.

25. General Electrical Safety Rules and Regulations:

- I. All the electrical apparatus including welding machine (either 3-phase or single phase) should be provided with Earth Leakage Circuit Breaker (ELCB/RCCB/RCBO) of 30mA rating.
- II. Bidder should ensure periodic checking of ELCB provided in their electrical apparatus.
- III. Bidder should ensure that there should not be any joint in the power supply cable of any machine. All cables should be in good condition with no bare insulation or frayed wires
- IV. Any power supply switchboard/extension boards brought by Bidder should have ELCB of 30mA rating and it should have sockets along with 3-pin plug
- V. Any type of cable brought by Bidder should not have any joint and should be of sufficient capacity for the respective job.
- VI. Bidder to bring their own 24V rating portable hand lamps along with cable of (apparatus should be having 230V / 24V transformer) for the temporary lighting arrangement required at site for the respective jobs.
- VII. Bidder should bring sufficient qty no. of temporary light fixtures (230V or 24 V as per requirement of job/contract) , extension boards, cables to draw supply from nearest power point.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

- VIII. Hand-held and portable machines shall be equipped with a built-in switch to switch off power in case of emergency
- IX. Bidder to ensure healthiness of their electrical equipment whenever brought to GIPCL site and get them tested / verified by GIPCL Electrical Department representatives before start using.
- X. Bidder to ensure - All portable electric apparatus shall be regularly examined, tested and maintained to ensure that the apparatus and leads are in good order.
- XI. Only three-core cable shall be used for single phase operated tools with the third core connected to earth.
- XII. Ensure that all metallic portable appliances are provided with 3 pin plug and socket connections with third pin be connected to the ground terminal where ever possible. Also, the metal work of the apparatus is effectively earthed.
- XIII. All cables and connections should be sound and of adequate capacity and properly insulated while using any welding machine and other power connections.
- XIV. The earthing arrangements should be properly made with earthing clamps or a bolted terminal while using any welding machine
- XV. Electric holders when not in use, should be placed on an insulated hook or the holders should be fully insulated while using any welding machine
- XVI. Whenever the welder stops or leaves work for any appreciable time, the power supply to welding machine shall be effectively disconnected while using any welding machine
- XVII. GIPCL will provide either single phase OR 3-phase 3 wire power supply from the nearby point at job site. Bidder to supply the required cable between GIPCL power supply point to equipment brought by Bidder for the specified job. Further, if Bidder's equipment requires 3-ph 4 wire supply then they should derive 3-ph 4 wire supply from GIPCL 3-ph 3 wire supply system by incorporating sufficient capacity transformer. Like for hydro jet cleaning system, mixer machine, induction heating machine, SR machine etc., GIPCL will provide 3-ph 3 wire power supply.
- XVIII. Cable between welding machine to GIPCL power supply point should have cable TOP plug towards GIPCL power supply point of Make BALS having rating as 63 Amp.

Contractors not following above electrical safety points at any point of time are liable to penalty and their machine/ apparatus shall be seized by GIPCL.

16. REJECTION OF WORK:

If, as a result of inspection, examination or testing, the GIPCL's Representative/Engineer decides that any materials, work or workmanship is defective or otherwise not in accordance with the Contract, the GIPCL/Engineer/ GIPCL's Representative may reject such plant, materials, work or workmanship and shall notify the CONTRACTOR promptly, stating his reasons. The CONTRACTOR shall then promptly make good the defect and ensure that the rejected item complies with the Contract. If Contractor failed to rectify the rejected work or workmanship, GIPCL/Engineer reserves the right to deduct or withhold amount against rejected work or Workmanship. CONTRACTOR shall not entitle for any claim or release of hold payment until rectify the defect up to satisfactory of GIPCL. If Contractor failed to rectify any such defective work or workmanship, GIPCL reserve the right to rectify at risk and cost of the CONTRACTOR and deducted by the GIPCL from any amount due, or to become due, to the CONTRACTOR's dues.

If the GIPCL/Engineer/GIPCL's Representative requires such materials, work or workmanship shall be retested, the tests shall be repeated under the same terms and conditions. If such rejection and retesting cause the GIPCL additional costs for the traveling and lodging costs of GIPCL/Engineer's personal for attending the retest, such costs shall be recoverable from the CONTRACTOR by the GIPCL and may be deducted by the GIPCL from any amount due, or to become due, to the CONTRACTOR.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

17. GENERAL TERMS AND CONDITIONS FOR APPLICATION OF SOOT BLOWER WORK:

- a) All tools & tackles, labours, equipment, vehicles, tractors, lapping compound with lapping kit, Welding rod for rod welding etc... to execute the contract are in the scope of the contractor. The contractor should ensure that tools & equipment are in healthy condition. All required, grinding machine, cutter machine lighting arrangement, etc... are in the scope of the contractor with all safety precaution, the decision of the Engineer-in-charge shall be final and binding on the contractor for defining the terms and condition included in this contract. If the work is not found satisfactory, Engineer-in-charge reserves the right to take suitable action.
- b) Contractor shall depute Location/Package wise full time independent experienced site-in-charge / Engineer / Supervisor, Foreman, Store keeper,. They shall co-ordinate with GIPCL engineer and shall bear overall responsibility of contract including joint measurement, billing etc. Such person shall function from site office of contractor at SLPP.
- c) Contractor shall strictly follow the existing work permit system of the GIPCL and any future revisions.
- d) The contractor has to take EC insurance policy for their workmen. The contractor has to submit labor license and PF account number to the Engineer-in-charge before start the work.
- e) The contractor has to do the job timely. GIPCL shall not compromise in delay. In case of delay of work without any valid reason, the GIPCL reserves the rights to carry out the work by deploying other agencies at the risk & cost of contractor with additional 10% overhead charges.
- f) The scope against each activity mention in Part B also cover receipt / transfer spare material from ware house, renewal of PTW on daily basis against work , removal of any scrap generated out of work executed as per instruction and procedure suggested by engineer in charge.
- g) Contractor must fulfil all the safety regulations and to take safety measures to avoid hazards. Contractor shall arrange all standard adequate healthy safety PPEs like but not limited to approved quality safety shoes& safety helmets, standard dust masks, safety goggles, etc... as required and shall use exclusively under this contract for all the time during working at specified locations failing which, the Engineer-in-charge may hold the work and will take necessary action including penalty as decided. If the contractor repeatedly violates safety rules/regulations (more than three successive incidents), Engineer-in-charge may take necessary action against the contractor, including appropriate financial penalty and/or termination of contract.
- h) One or more jobs may be required to be done simultaneously and contractor shall mobilize additional resources accordingly.
- i) Timely completion of all jobs and works shall be the essence of this Contract. Contractor should closely monitor each activity and complete the jobs as per the time given by and under the supervision of the Engineer-In-charge and shall ensure that sufficient manpower is deployed for the same.
- j) The contractor has to complete the works as per the planning schedule and their respective supervisor has to interact with Engineer In Charge for PTW (Permit to work), work instruction, Return of permit.
- k) The contractor has to submit daily reports showing work carried out with details of available manpower, resources etc.
- l) Any job other than the listed jobs in work order shall be executed by the contractor on “Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

instruction from GIPCL and payment shall be made to the contractor on respective item rate only.

- m) The Government of India has enacted the Micro, Small and Medium Enterprises Development Act, 2006 (the "Act") and the Act has come into force from October 2, 2006. The Bidder shall confirm whether your organization is registered under the Micro, Small and Medium Enterprises Development Act, 2006. If your organization is registered under the Act, please specify the category i.e., Micro Enterprise, Small Enterprise or Medium Enterprise under which it is registered and kindly attach a copy of your registration certificate.
- n) The Bidder shall provide details of registration along with copy of the registration certificate issued by the District Industries Centre/Department of Industries, etc of the respective State Government. It is to be noted that large scale industries and trading firms have been excluded from the purview of the Act.
- o) GIPCL is an ISO 9001, ISO 14001, OHSAS 18001 & ISO 50001:2011 (EnMS) certified company, and GIPCL gives extreme importance to maintain these global standards. Contractor shall be required to observe these standards while working with GIPCL. Contractor should ensure that his workmen/labour work in accordance with them.

18. CONTRACTOR'S SUPERVISION

The contractor shall, during the whole time the work is in progress, employ a qualified experienced site-in-charge of the works with adequate experience in handing of jobs of this nature and with the prior approval of the GIPCL / ENGINEER. Such in-charge shall be constantly in attendance at the site during working hours. During CONTRACTOR'S supervisory engineer absence during working hours, if unavoidable, and also beyond working hours, when it may be necessary to give directions, orders may be given by the ENGINEER / GIPCL and shall be received and obeyed by the CONTRACTOR'S superintendent or Foreman who may have charge of the particular part of the work in reference to which orders are given. If requested to do so, the ENGINEER /GIPCL shall confirm such orders in writing. Any directions, instructions or notices given by the ENGINEER / GIPCL to him, shall be deemed to have been given to the CONTRACTOR. The representative of the CONTRACTOR shall have all necessary powers to receive materials from the GIPCL, issue valid receipts for the same, engage labour or purchase materials and proceed with the work as required for speedy execution.

None of the CONTRACTOR'S Superintendents, engineers, supervisors or labour should be withdrawn from the work without due notice being given to the GIPCL / ENGINEER; further no such withdrawals shall be made if in the opinion of the GIPCL / ENGINEER such withdrawals will jeopardize the required pace of progress / successful completion of the work.

The CONTRACTOR shall employ in or about execution of the work only such persons as area careful, skilled and experienced in their respective trades, and the GIPCL shall be at liberty to object to and require the CONTRACTOR to remove any person employed by the CONTRACTOR in or about execution of works who in the opinion of the ENGINEER misconducts himself or is incompetent or negligent in the proper performance of his duties and all such persons shall not again be employed upon the works without the prior permission of the GIPCL.

Neither the CONTRACTOR and the PURCHASER nor the ENGINEER shall hire or employ any employee of the other party except by mutual consent.

19. CONTRACTOR TO REMOVE ALL OFFENSIVE MATTER IMMEDIATELY AND CLEAN-UP.

All loose materials, wastage, packing materials, cut pieces or other matter of an offensive nature shall not be deposited on the surface, but shall at once be carted away by the CONTRACTOR to some pit or place provided by him away from the site of work and approved by local authorities.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

As a part of the work included in this contract, the CONTRACTOR shall completely remove and satisfactorily dispose of all temporary works to the extent directed. He shall tear down and dispose of all temporary works, shall remove or grade, to the extent directed, all plant and equipment, shall satisfactorily dispose off all rubbish resulting from the operations under this contract and shall do all work necessary to restore the territory embraced within the site of his operations to at least as good order and conditions as at the beginning of the work under this contract.

20. FACILITIES TO BE PROVIDED BY GIPCL

The Company shall provide the following facilities to the Contractor at the site:

- a. Electricity & water at nearest available one point. Further distribution to be done by contractor at their cost.
- b. Quarter(s) for supervisor/ engineers on chargeable basis in GIPCL's township at discretion of GIPCL if available.
- c. Workshop facility as available at site only.
- d. Hydra and Tractor will be provided for lifting/shifting the heavy items subject to availability and chargeable basis only.
- e. Canteen facilities shall be provided on chargeable basis as per company policy.
- f. Space for storing of supplied material.
- g. First Aid facility as available
- h. Soot Blowers all spares, Diesel, grease, oil, fasteners, gland and gasket, Scaffolding material and Scaffolding erection.
- i. Require welding and Gas cutting work for soot blower related work.
- j. For part C manpower required for lifting / shifting heavy parts will be provided by GIPCL on need base.

Apart from the above, no other facilities shall be provided by GIPCL.

The contractor shall provide necessary facilities including accommodation of their labour at their cost.

The Contractor has to collect above items from GIPCL stores/warehouse and shifting arrangement has to be made by Contractor at his own cost. Contractor shall give report/reconciliation of the issue of materials drawn.

GIPCL shall also conduct an orientation programme appraising the workmen regarding the safety norms and measures to be observed during work operations at the plant site.

21. WORK MEASUREMENT/CERTIFICATION

The work to be performed being a specialized nature, the contractor should be fully conversant with modern practices and should be able to carry out works independently of large thermal power plant. The contractor shall therefore be required to engage qualified/ experienced personnel to undertake the work as per specifications and requirement.

Contractor should maintain one computer with printer for keeping daily records and maintain the data.

All the work measurements shall be jointly recorded in a measurement sheet/register/relevant documents by the contractor I authorized representative of the contractor and the Engineer-in-charge. The measurements shall be clearly written indicating date of measurement, location, reference to drawings, if any, and jointly signed.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

The Contractor shall be required to furnish satisfactory job completion report to GIPCL including before and after work all photos. The submission of report should be on daily basis, the monthly bill payment shall be released based on the certified reports of the works.

Inspection of work will be done by Engineer in Charge or his authorized representative. If the work is not found satisfactory engineer in charge reserves the right to take suitable action and shall be binding to the contractor.

22. PUBLIC HOLIDAYS

The Contractor shall be responsible for giving benefit to all his employees, employed in whatsoever capacity, 09 Public/Paid holidays and the same shall be notified in advance and due communication thereof shall be made to the Management.

23. BENEFIT PAYABLE IN CASE OF ACCIDENT OCCURRING OUTSIDE PREMISES OR BEYOND THE COURSE OF EMPLOYMENT

The Contractor shall provide an insurance coverage (Medical + Death Benefit) for sum of Rs. 01/- Lakh to all his workmen/labour deployed at GIPCL-SLPP site for the accident taking place anywhere outside the Company premises or at any place when the workman is not in course of his employment.

24. FORCE MAJEURE

The performance of the obligations herein contemplated may be suspended without incurring the penalty in the event of the subsistence of Force Majeure conditions.

If a Force Majeure situation arises, the affected Party shall promptly notify the other Party in writing of such conditions and the performance shall be suspended as per mutual agreement.

For the purposes of this clause, 'Force Majeure' means an event beyond the control of the Party and not foreseeable by the Party and shall include events of floods, explosions, riots, wars, hurricane, epidemics, any other Act of God, quarantine restrictions, terrorism, government actions and provided always that such acts result in the impossibility of the further performance of the contract.

25. INDEMNITY

The Contractor shall indemnify and keep harmless GIPCL from and against all actions, proceedings, claims, demands, losses, costs, damages and expenses whatsoever which may be brought against or suffered by GIPCL which it may sustain, pay or incur as a result of or in connection with the performance/ purported performance/ non-performance of the contract by the Contractor.

In case, in any litigation pertaining to labour employed through contractor if any direction or order is issued by court at any point of time the contractor shall comply with and implement such direction or order whether passed at the time of award of contract or during the pendency of contract. Further, the Contractor shall indemnify the GIPCL against all consequences arising and affecting GIPCL owing to the compliance of the orders by the Contractor.

26. GOVERNING LAW AND JURISDICTION

This tender document and contract shall be governed by the laws of India and the Courts at Surat shall have jurisdiction regarding the same.

Where any portion of the General Condition of Contract is repugnant to or at variance with any provisions of the Special Condition of Contract, then unless a different intention appears, the provision of the Special Conditions of Contract shall prevail to the extent of such repugnancy of variance.

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

SECTION-D

SPECIAL CONDITIONS OF CONTRACT

1. DETAIL SCOPE OF WORK

Already mentioned in section -A point no 3

1.1. FAILURE DURING EMERGENCY

During any emergencies, contractor shall have to carry out the work by deploying additional force within twenty-four hours notice period failing which GIPCL reserves the right to carry out this work by engaging other contractor. The expenditure occurred due to such situations, the Contractor will be held responsible & the same will be recovered from the Contractor's monthly bill / any other pending bills along with 10% overhead charges. For repetitive failure of such work for more than two incidents, GIPCL reserve the right to terminate the entire contract by forfeiting all pending dues, Security Deposit & other retention money, if any, after giving 15 days notice to the contractor & this will be binding to the contractor.

1.2. TO REMEDY DEFECTIVE WORK

If the work or any portion thereof shall be damaged in any way excepting by the acts of the GIPCL, or if defects not readily detected by proper inspection shall develop before the final completion and acceptance of the whole work, the CONTRACTOR shall forthwith make good, without compensation, such damage or defects in a manner satisfactory to the ENGINEER / GIPCL. In no case shall defective or imperfect work be retained even if contractor followed all technical specifications. GIPCL will not compromise for quality of materials, works & workmanship.

The CONTRACTOR shall remain liable under the provisions of this clause notwithstanding the passing by the GIPCL of any certificate, final or otherwise or the passing of any accounts.

1.3. DAILY DIARY AND PROGRESS REPORT:

A daily diary register will be kept in the ENGINEER'S office. The CONTRACTOR will supply all detailed information every day at 9:00 hours for the day preceding and the diary will be jointly signed by the ENGINEER and the CONTRACTOR'S representatives, every day in token of its correctness. A works instruction book, serially numbered will also be kept in the ENGINEER'S office and all day to day instructions will be given in that book. The CONTRACTOR'S representative shall report every day to see these instructions and sign them at the bottom in token of his having seen them.

The CONTRACTOR shall provide all information regarding procurement of materials and progress of work, as is required by the ENGINEER for compiling the weekly progress reports. This information shall be provided by contractor at 9:00 hours every Monday, for the preceding week.

2. PRICE & RATES

The rates quoted by the Bidder in the online Price Bid shall be inclusive of cost of all labor, supervision, cost of safety supervisor, shifting, transportation, loading, unloading, equipment, all tools & tackles, safety equipment & PPEs, Royalties, Rents, GST, Stamp Duties, Central or State Government or Local body or Municipal Taxes or Duties, Turn over Tax, Work Contract Tax, and / or any other duty / tax, levied by the Central, State Government or other Public bodies etc...and such other costs that are not specifically mentioned herein but will be incurred by the contractor for the satisfactory and timely completion of the work. The quoted rates shall be deemed to include for "Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26".

everything mentioned in the specification, all leads & lifts, contractor's overheads & profits for due performance of the work under this contract and such other costs that are not specifically mentioned herein but will be incurred by the contractor for the satisfactory and timely completion of the work. The rates shall also include cost for mobilization / demobilization of manpower, equipment, materials, etc...

The rates shall be firm for entire contract period and also during extension, if required and shall not be subject to any escalation in prices, idle charges for labor, machinery, overhead expenses etc. No price escalation / idle charges shall be due to any reason whatsoever.

The prices / item rates quoted by Bidder shall remain firm till completion of the contract period and any agreed extensions thereafter and shall not be subject to any other escalation, idle charges for labor, machinery, overhead expenses etc. No price escalation / idle charges shall be payable due to delay in work by contractor or due to non-availability of work front by GIPCL or any reason whatsoever.

The price/rate quoted by CONTRACTOR shall be considering mobilization of all required manpower, tools & tackles, materials, equipment for timely and satisfactory completion of all scope of work.

The value and/or quantum of work may be increased or decreased depending upon day to day requirement. However, item rates remain unchanged and the payment shall be made as per the actual quantity executed as informed & certified by GIPCL representatives.

3. TERMS OF PAYMENT

A. Conditions of Payment:

The contractor shall raise the invoice in duplicate in respect of the work performed or completed along with the documents as hereinafter provided. On receipt of the invoice complete in all respects and with all the said documents, the payment in respect of the same shall be made within 21 days of such receipt of a complete invoice as per the following terms of payment –

- i) 100% payment against the work executed duly certified by GIPCL E-I-C and on submission of joint protocol with drawing / photo album in soft & hard copy indicating the details of repaired portion on drawing and with quantity of applied material and material reconciliation report. Payment shall be made unit wise.
- ii) Security deposit at 10% of Annual contract value excluding taxes & duties shall be kept as a performance guarantee and shall be release after retention period of four month (04) after completion of contract period.
- iii) GST shall be paid along with bills after fulfilment of following terms.
 - (a) Submission of copy of registration certificate issued by GST Authority (to be furnished only once).
 - (b) Citing the GST Registration no. And the date of issue of registration certificate on invoices.
 - (c) Claim of GST amount with percentage (%) separately shown on the invoices.
 - (d) The contractor shall be required to submit the proof of payment of GST of previous month/quarter, as may be applicable as & when demanded by GIPCL/Owner/company.
 - (e) The Bidder shall inform the GIPCL in the event its registration certificate is cancelled or discontinued for whatsoever reason.
 - (f) The vendor shall also mention on their invoice the HSN/SAC code as applicable under the GST laws under which GST is levied and a self-certified authentic third-party

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

evidence (www.cbic-gst.gov.in) shall be adduced, one time, to that effect by the vendor.”

- iv) The Contractor shall submit his Final Bill within a period of four months of the expiration or earlier termination of the contract or any extensions that may be granted by GIPCL to the Contractor. GIPCL shall not entertain any bill for any work item after expiration of period of three months.
- v) The Contractor shall include all his claims in the Final Bill submitted by him and accordingly the final bill submitted by the Contractor shall be deemed to be inclusive of all and whatsoever the claims that the Contractor may have from GIPCL. The Contractor shall not be entitled to claim any amounts which are not mentioned in the Final Bill and the Contractor shall be deemed to have waived any claims not mentioned in the Final Bill and shall not be entitled to recover the same from GIPCL subsequent to the submission of the Final Bill on any account and GIPCL shall stand absolved of all its liabilities in respect of any such claims not raised by the Contractor in his Final Bill.

At the time of return of the Security Deposit, the Contractor shall submit no claim- no arbitration certificate and an indemnity bond acknowledging the receipt of all the due amounts and indemnifying GIPCL from and against all claims in that regard

B. Validity and Uniformity of Rates

The rates shall be valid throughout the Contract Period and shall remain unaltered during the entire Contract Period.

Item rates quoted, shall include cost of all consumables, (except free issue materials by GIPCL) labour, supervision, tools & tackles, transport and any such other costs excluding statutory taxes as are not specifically mentioned herein, but may be incurred by the contractor for the satisfactory and timely completion of the work and ideal time of non-allocation or less allocation of work during the contract period.

Deductions from Contract Price

All costs, charges or expenses payable by the Contractor under the terms of the contract or as per the applicable laws, in respect of which he makes default in payment, shall be the liability of the Contractor. Such amount or due may be paid by the Company and the Company shall be entitled to recover the same from the Contractor by deducting the said amounts from the Contractor's monthly RA bills.

4. MOBILIZATION AND EXECUTION

- a) Contractor shall mobilize the resources at site within 7 days the intimation given by GIPCL.
- b) Contractor shall provide required separate & independent site supervisors who will be responsible for supervision and execution of job in specified time with respect to quality, specifications, site preparations, safety, co-ordination with GIPCL, issue of work permits, joint measurements, etc... The supervisors shall coordinate with the Engineer-in-charge of GIPCL for proper execution of the job.
- c) The resources required for execution of above jobs will vary from time to time, hence contractor shall mobilize the resources accordingly.
- d) Contractor shall provide accommodation for the persons deployed by him for the work at his own cost.

5. QUANTITY OF WORK

The estimated quantities of work required to be carried out by the contractor are as given in the Section-E {Schedule of Quantity}. estimated and shall vary according to the exigencies of work at site. However, the rates quoted by Bidder shall remain firm irrespective of any variation in estimated quantities. Contractors shall engage required nos. of labors along with required tools & “Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

tackles as per work load and emergency situations throughout the contract period to perform his contractual duties.

In case, contract quantity/amount exhausted before completion of contract period, GIPCL reserve the rights to increase the quantities or contract amount for successful completion of entire contract period. Contractor shall responsible to complete the particular job up to entire satisfaction of Engineer-in-charge. The item rates remain firm & unchanged till completion of the contract and any agreed extensions thereafter and shall not be subject to any escalation, idle charges for labor, machinery, overhead expenses etc... for any reason whatsoever. The quantum of work of individual item may be up to any extent depending upon requirement. However, item rate remains unchanged. Under this contract, contractor has to execute all work as per the Plant requirement.

6. GENERAL CONDITIONS OF CONTRACT

General Conditions of Contract and detail specification prepared by the company will be applicable for this contract. The same is enclosed herewith. Bidders are advised to go through the same.

Where any portion of the general conditions of contract is repugnant to or at variance with any provisions of the special conditions of contract, then unless a different intention appears, the provision of the special conditions of contract shall prevail to the extent of such repugnancy of variance.

7. COVID-19

Contractor has to strictly follow the GIPCL Guideline for COVID-19 and Government policy time to time.

8. PENALTY AND RECOVERY

- a) In the event of undue delay in performance or the performance is unsatisfactory causing damage to the plant and property of GIPCL, then in such a case, GIPCL (Engineer-In-Charge) shall be entitled to levy a penalty on the Contractor at the rate of 1.5 times of the item rate up to a maximum of 10% of the total contract value. The said penalty amount may be recovered either from the monthly bills or the SD.
- b) However, the total amount of penalty recoverable from the Contractor shall be restricted to 10% of the contract value.
- c) In addition to and without prejudice to the above, GIPCL shall also have the right to get the affected work completed by a third party or agency at the risk and cost of the Contractor along with 10% overhead charges and the Contractor shall be liable for payment of any differential amount in the contract price.
- d) Any damage caused to the equipment or machinery on account of the negligence on the part of the Contractor or due to any other reasons attributable to the Contractor, shall be recovered by the Owner/GIPCL from the Contractor.
- e) The ascertainment of the cause of the damage shall be done by the GM (SLPP) and his decision in this regard shall be final & binding to the contractor.
- f) The decision of the Engineer-In-Charge as regard the amount of damages to be recovered from the Contractor shall be final.
- g) The aforesaid amounts of penalty and damages shall be recoverable from the monthly bills of the Contractor or the SD. If the amount of damages recoverable from the Contractor exceeds the bills and SD amount, then the Contractor shall become liable to pay the same to GIPCL and GIPCL shall be entitled to initiate appropriate proceedings against the Contractor for the same.

9. TERMINATION

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

GIPCL may terminate the contract after due recoveries of pending jobs/damages after giving 15 days' notice to the contractor if any of the following events occur :-

- a) Contractor is adjudged as insolvent.
- b) Contractor has abandoned the contract i.e. the Contractor fails to perform the obligations under the contract for a period of One month.
- c) Contractor fails to proceed with the work with due diligence as per requirements of the contract.
- d) Any of the licenses, permissions or registrations of the Contractor as required under the applicable laws are discontinued/ cancelled or not renewed in time.
- e) Contractor has neglected or failed persistently to observe or perform his obligations under the contract or performs unsatisfactorily
- f) The Contractor is found to have acted in breach or violation of any of the safety norms persistently, applicable labour and other laws in relation to the contract and his obligations therein. The Contractor commits a breach of the contractual terms and conditions.

GIPCL shall give the Contractor a 15 days' notice period to rectify the breach, failing which the contract shall stand terminated on the last date of the notice period without requiring any further notice from GIPCL in that behalf.

Upon such termination

,the outstanding dues of the Contractor shall be settled subject to the amounts recoverable by GIPCL under the contract from the Contractor.

The SD shall be retained till completion of the defect liability period.

SECTION – E

ANNEXURE – F1

Price Schedule (TO BE FILLED ONLINE ONLY)

Sr. No.	Description	Total Qty A	Unit	Final Price B	Total Final Price C = A x B
1	Lump sum Mobilization and Demobilization charges per visit (Including To & Fro travel charges by train, tools & tackles, Boarding and lodging, Local travelling and all other incidental expenses...etc) of Two Units Boiler during AOH	2	Nos.	To be Submitted Online	Will be calculated by System
2	Complete Servicing of LRSB & HRSB as per the given below scope of work for Two Units Boiler during AOH	16	Nos.	To be Submitted Online	Will be calculated by System
3	Lump sum Mobilization and Demobilization and Inspection of healthiness of soot blowers - if required complete Servicing and replacements of components of LRSB & HRSB (Total 144 nos. Soot blowers, Site work at least 07 days at site with minimum 01 Service engineer + 03 technician) in Unit 1,2,3&4 Boiler during FSD / as & when require	1	Nos.	To be Submitted Online	Will be calculated by System
4	Sub Total (Sum of Sr no 1 to 3)				Will be calculated by System
5	Add GST at 18% on Sr no 4				To be Submitted Online
6	Grand Total (Sum of Sr no 4 & 5)				Will be calculated by System

Note:

- Price & rates quoted above shall include cost of all consumables (except free issue materials by GIPCL) labor, supervision, tools and tackles, transport etc. and such other cost are not specifically mentioned herein but will be incurred by the contractor for the satisfactory and timely completion of the work.
- Payment shall be made as per actual execution of work.
- Contractor has to arrange lodging & boarding facilities to their supervisors, technician & labors on their own. GIPCL will not provide above facility.
- Quantity is indicative and it may vary as per site requirement.
- Quantity mentioned above may be utilised for any unit of the SLPP.
- Please refer Part B in Scope of work while quoting rates.
- Mobilization for AOH of two unit shall be considered as separate mobilizations for part A.

COMPANY SEAL

SIGNATURE
NAME
DESIGNATION
COMPANY
DATE

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

SECTION – F (ANNEXURES)

ANNEXURE – F

BID FORM

BID NO.:

From :

To :

M/S GUJARAT INDUSTRIES POWER COMPANY LIMITED
Surat Lignite Power Plant
At & Post – Nani Naroli
Taluka – Mangrol
Dist. Surat – 394110

1. I / We, the undersigned, have carefully examined and understood the Bidding Documents. I/We hereby agree for the annual maintenance contract described in the specifications (or such portion thereof as Gujarat Industries Power Company Limited may accept) in conformity with the Specifications and Bidding documents.
 - (a) The total price for the rate contract of equipment specified for annual maintenance contract being (in figures)
..... (in words)
.....
 - (b) The equipment will be maintained in accordance with the instruction of supplier.
2. In the event our proposal is accepted, we agree to furnish a performance Guarantee in the manner acceptable to Gujarat Industries Power Company Limited, and for the sum equal to 10% of Annual Contract Price (excluding GST) within 21 days of the 'Letter of Intent / Letter of Award'.

COMPANY SEAL

SIGNATURE

NAME

DESIGNATION

COMPANY

DATE

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

**ANNEXURE-A
CHECKLIST FOR PASSING THE BILLS**

	For the month of		
1) Work Order / P.O. No. & Contract value			
2) Nature of work			
3) Duration of Work Order	From		to
4) Maxi. No. of manpower per day deployed in the month.	M	F	Total
Details of Labor License to Persons.	Valid up		for
Details of E.C Policy to Persons.	Valid up		for
7) Documents attached for verification for the previous month.	Wage & Attendance Sheets.		Yes/No
	P.F Challan		Yes/No
8) Documents attached for verification (in case of Final Bill)	Bonus Payment Register		Yes/No
	Leave wage register		Yes/No
9) Security Deposit / Retention Money lying with Co.	Date:		
Yes /No if yes, Rs	Signature of Contractor with official stamp		

ANNEXURE-C

CERTIFICATE

(No claim, No arbitration, To be submitted along with final bill on company's Letterhead)

To,
Addl. General Manager (SLPP)
Gujarat Industries Power Company Limited,
Surat Lignite Power Plant,
Village: Nani Naroli, Ta. Mangrol,
Dist. Surat – 394110 (Gujarat).

Dear Sir,

Subject: _____

Ref: Work Order No.: _____ Dated _____

We hereby confirm with free consent as under:-

1. The measurements certified in final bill is full and final. We accept all the certified measurements and no claim related to the measurement is left.
2. The payment certified in that or above referred Lol / contract is full and final. We accept this, and no claim related to payment is left.
3. The rates of the Lol / contract and its amendments are firm till completion of contract and extension period. We shall not claim any escalation against these rates.
4. Along with the contract referred, the ARBITRATION CLAUSE also perishes i.e. we will not resort to arbitration.
5. No extra items are left to be settled.
6. We do not have any claims against any item related to the Lol than those items certified in the bills.
7. We are accepting the recoveries or hold amount from our bills, if any, made by GIPCL against non compliance or as decided by GIPCL within terms & conditions of contract.
8. We have paid royalties, taxes for all the materials procured by us, for carrying out the works for above Lol and we indemnify GIPCL from any liability arising thereof.
9. In case of any disputes arising in future related to payment of royalties, all liabilities of settlement of dispute and its payment if any, will be borne by us.
10. We have paid wages to all the workmen who were deployed by us for carrying out above referred work as per prevailing Minimum wages act. We have also fulfilled all requirements of the P.F. Act. We have maintained all records necessary as per the statutory requirements. We hereby indemnify GIPCL from any disputes arising in future related to payment of labours, Provident Fund, etc.. and confirm that all liabilities of settlements of disputes and their payment is our responsibility.

The above confirmation will come into effect as soon as payment from final bill after due recoveries will be received by us.

For, M/S. _____

Signature, Stamp and date.

ANNEXURE-G
PROFORMA FOR BANK GUARANTEE FOR EARNEST MONEY DEPOSIT
(To be executed on non-judicial stamped paper of appropriate value)

B. G. No. ----- Date: -----

1. WHEREAS M/s. Gujarat Industries Power Company Limited having its Corporate Office at PO: Petrochemicals, Dist. Vadodara – 391 346, Gujarat State, India (hereinafter called “The Company Owner” which expression shall unless repugnant to the subject or context includes its legal representatives, successors and assigns) has issued tender paper vide its Tender No.....for ----- (hereinafter called “the said tender”)to M/s.....(hereinafter called the said Tenderer(s)” which expression shall unless repugnant to the subject or context includes their legal representatives, successors and assigns and as per terms and conditions of the said tender, the tenderer shall submit a Bank guarantee for Rs..... (Rupees.....only) towards earnest money in lieu of cash.
WeBank having its branch office at
2. do hereby undertake to pay the amount due and payable under this guarantee without any demur, merely on a demand from the Company stating that in the opinion of the company which is final and binding, the amount claimed is due because of any withdrawal of the tender or any material alteration to the tender after the opening of the tender by way of any loss or damage caused to or would be caused or suffered by the Company by reason of any breach by the said tenderer(s) of any of the terms and conditions contained in the said tender or failure to accept the letter of Intent Agreement or that the amount covered under this Guarantee is forfeited. Any such demand made on the Bank by the owner shall be conclusive as regards the amount due and payable by the Bank under this guarantee, However, our liability under this guarantee shall be restricted to an amount not exceeding Rs.....(Rupees.....only).
3. We undertake to pay to the Company any money so demanded notwithstanding any dispute or disputes raised by the tenderer (s) in any suit or proceeding pending before any office, court or tribunal relating thereto our liability under this present guarantee being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment there under. Our liability to pay is not dependent or conditional on the owner proceeding against the tenderer.
4. The guarantee herein contained shall not be determined or affected or suspended by the liquidation or winding up, dissolution or change of constitution or insolvency of the said tenderer(s) but shall in all respect and for all purposes be binding and operative until payment of all money due or liabilities under the said contract(s)/ Order(s) are fulfilled.
5. WeBank Ltd. further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the finalization of the said tender and that it shall continue to be enforceable till the said tender is finally decided and order placed on the successful tenderer(s) and or till all the dues of the company under or by virtue of the said tender have been fully paid and its claims satisfied or discharged or till a duly authorized officer of the company certifies that the terms and conditions of the said tender have been fully and properly carried out by the said tenderer (s) and accordingly discharges the guarantee.
6. That the Owner Company will have full liberty without reference to us and without affecting this guarantee to postpone for any time or from time to time the exercise of any of the power of the owner under the tender.
7. Notwithstanding anything contained herein before, our liability shall not exceed Rs..... (Rupees.....only) and shall remain in force till..... (Date to be filled up shall be 180 days from the date of submission of Bid).

Date.....

..... Bank Corporate
Seal of the Bank By its constitutional Attorney

Signature of duly Authorized person
On behalf of the Bank
With Seal & Signature code

Annexure - K

CONTRACT SECURITY-CUM-PERFORMANCE GUARANTEE BY SELLER / CONTRACTOR.

(To be executed on non-judicial stamped paper of approximate value)

B. G. No. ----- Date: -----

1. WHEREAS Gujarat Industries Power Company Limited having its office at PO: Petrochemicals, Dist. Vadodara – 391 346, Gujarat State, India (hereinafter referred to as “The Company/Owner” w h i c h expressions shall unless repugnant to the subject or context includes its legal representatives, successors and assigns) has entered into a contract with M/s. / has placed a purchase order on M/s.....(hereinafter referred to as “Contractor(s)/ Seller(s)” which expression shall unless repugnant to the subject or context includes their legal representatives, successors and assigns) foron the terms and conditions as set out inter alia, in the Company’s contract No./ P.O. No.....dateand various documents forming part thereof hereinafter referred to as the “said contract” which expression include all amendments, modifications and/ or variations thereto and where as the Contractor(s)/ Seller(s) has agreed for due execution of the entire contract and guarantees its performance including any parts executed through any other agencies/ subcontractors. AND WHEREAS one of the conditions of the “said contract” is that “contractor(s)/seller(s) shall furnish to the owner a Bank Guarantee from a bank for....% (.....percent) of the total value of the “said contract” against due and faithful performance of the “said contract” including performance guarantee obligations of the contractor(s)/seller(s) for execution/ supplies made under the “said contract.”
2. WeBank having its branch office atdo hereby agree and undertake to pay the amount due and payable under this guarantee without any demur merely on a demand from the Company stating that in the opinion of the Company, which is final & binding, the amount claimed is due by reason of default made by the Contractor(s)/ Seller(s) in performing any of the terms & conditions of the said Contract including defect liability obligations, in fulfilling the performance guarantee obligation or loss or damage caused to or would be caused to or suffered by the Company by reason of any breach by the said Contractor (s)/ Seller(s) of any of the terms & conditions of the contract. Any such demand made on the Bank by the owner shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to Rs. (Rupees.....only).
3. We undertake to pay to the Company any money so demanded not withstanding any dispute or disputes raised by the contractor(s)/ Seller(s) in any suit or proceeding pending before any office, court or tribunal relating thereto our liability under this present guarantee being absolute and unequivocal. The payment so made by us under this bond shall be a valid discharge of our liability for payment there under. Our liability to pay is not dependent or conditional on the owner proceeding against the Contractor(s)/ Seller(s).
4. The guarantee herein contained shall not be determined or affected or suspended by the liquidation or winding up, dissolution or change of constitution or insolvency of the said Contractor(s)/ Seller(s) but shall in all respect and for all purposes be binding and operative until payment of all money due or liabilities under the said contract(s)/ Order(s) are fulfilled.
5. This guarantee will remain valid up _____ days or _____ whichever is earlier. The Bank undertakes not to revoke this guarantee during its currency without previous consent of the OWNER/PURCHASER and further agrees that if this guarantee is extended for a period as mutually agreed between bidder & owner/purchaser, the guarantee shall be valid for a period so extended provided that a written request for such extension is received before the expiry of validity of guarantee.
6. WeBank further agree with the Company that the company shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Contract(s)/ Order(s) or to extend the time of performance by the said Contractor(s) “Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

Seller(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by the Company against the said Contractor(s)/ Seller(s) and to forbear or enforce any of the terms and conditions relating to the said Contract(s)/ Order(s) and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Contractor (s) / Seller(s) or for any forbearance, act or omission on the part of the Company or any indulgence by the Company to the said Contractor(s)/ Seller(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have affect of so relieving us.

7. Notwithstanding anything contained herein before, our liability shall not exceed Rs.....(Rupees.....only) and shall remain in force till.....Unless a demand or claim under this Guarantee is made on us within three months from the date of expiry we shall be discharged from all the liabilities under this guarantee.

Date.....
Corporate Seal of the Bank

.....Bank
By its constitutional Attorney Signature
of duly Authorized person
On behalf of the Bank
With Seal & Signature code

ANNEXURE- I

Eligibility criteria for insulation application tender participation.

Sr. No	Eligibility Criteria [inline with clause-5]	Year	Rs. Lacs	In	Details	Supporting Documents attached.
1	Bidder should possess minimum three years of experience during last five years in Supply of LRSB HRSB spares or servicing of Long Retractable soot blower & half retractable soot blowers in lignite or coal fired units (Party should have similar type of servicing of LRSB & HRSB or Supply of soot blower spares in 100MW or more capacity boilers). Proof to be attached. Bidder shall submit necessary evidence for the same like self-attested copies of work order/ work execution / Work completion certificate from client. The work completion certificate shall comprise of order value & executed value. Bidder should have executed the work directly. The work order executed as a sub contractor or subletting agency shall not be taken in to consideration.	2023-24				
		2022-23				
		2021-22				
		2020-21				
		2019-20				
2	Bidder should have average annual turnover of 4.76 Lakh for last three financial year (2023-24, 2022-23, 2021-22). Bidder shall furnish annual audited financial statement duly certified by Chartered Accountant (Certified by/from a qualified Chartered Accountant, being a member of the Institute of Chartered Accountants of India) for the last three years to demonstrate the financial healthiness of the company. The balance Sheet and profit & loss account must be in the name of company. Any type of MOU for this purpose will not be entertained. Copies of the same shall be submitted. Note – In case the annual turnover is less than the statutory guideline which does not require audit, the bidder shall submit the turnover certificate from chartered Accountant. (Certified by/from a qualified Chartered Accountant, being a member of the Institute of Chartered Accountants of India)	2023-24				
		2022-23				
		2021-22				
3	The net worth of the bidder should be positive as evidenced from audited accounts of last financial year - 2023-24.					
4	Bidder shall furnish annual audited financial statement duly certified by Chartered Accountant (certified by/from a qualified Chartered Accountant, being a member of the Institute of Chartered Accountants of India)for the last three years to demonstrate the financial healthiness of the company. The balance Sheet must be in the name of the company. Any type of MOU for this purpose will not be entertained.	2023-24				
		2022-23				
		2021-22				
5	Bidder should produce evidence of having experience of successfully completed identical works as defined hereunder during last three years of last five years	2022-23				
		2021-22				
		2020-21				

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

	<p>ending last day of the month previous to the one in which tender is invited, satisfactory progress of ongoing works etc. along with certified copies of documentary evidence preferably photo copies of work experience from the clients. Secured from clients along with self attested copies of documentary evidence preferably photo copies of work experience.</p> <p>The experience should be either of the following:</p> <p>Bidder should have executed minimum (for Supply of soot blower spares or servicing of LRSB & HRSB in lignite or coal fired units in boiler (Party should have similar type of service or supply of soot blowers 100MW or more capacity boilers)</p> <p>One similar completed work each costing not less than the amount equal to 12.70 Lakh OR Two similar completed work each costing not less than the amount equal to 7.93 Lakh OR Three similar completed work each costing not less than the amount equal to 6.35 Lakh</p> <p>Bidder should specifically mention fulfilling of above criteria in the offer along with details of work orders / work completion certificates issued by clients</p>	2019-20			
		2018-19			
6	Contractor has to submit Work Order / satisfactory work completion certificate / Performance certificate issued by clients from the client. Experience as a sub-contractor will not be allowed and Price Bid of such Bidders will be rejected.				
7	Bidders should possess valid PF number.				
8	Bidder shall enclose P. F. code allotment letter along with labour licenses and W.C. Policy copies of previous orders.				
9	The bidder has to submit PAN Card copy of the firm/Company.				
10	Bidder has to submit copy of GST registration number. Copy of same should be submitted.				
11	Bidder has to submit GST registration number				
12	After opening of technical Bid, if any required attested documents found missing in the Technical Bid submitted by the Bidder, the tender inviting authority may inform to that Bidder only once by E-mail to submit the missing required documents within stipulated time limit. If Bidder/Bidders fail to submit within stipulated time, their Bid will be declared technically disqualified and no further correspondence will be entertained.				
13	Tender fee: to be paid only by RTGS/NEFT/IMPS/Net Banking/Online Mode				

14	EMD: To be paid only by RTGS/NEFT/IMPS/Net Banking/Online Mode. In case of Bank Guarantee, the BG shall be in favor of GIPCL from approved Banks mentioned in this tender. or Bank Guarantee given by Bank as described in subsequent clause.				
15	Attested copies of relevant documents duly signed & seal on each & every page shall be submitted. The above documents will be analyzed and after satisfaction, the Price Bid will be open.				
16	Declaration Cum Undertaking for Safety Laws and Regulations Compliance (ANNEXURE- M)				
17	Declaration for Contractual Disputes/ Litigations (ANNEXURE- N)				
18	Previous work order copies				
19	Present ongoing work details				
20	Eligibility criteria as per tender Annexure I (Supporting documents to be must attached)				
21	Qualification and experience of site in charge / site Engineers and supervisors				
22	Schedule of deviation (Annexure- J) Technical as well as commercial, if any				
23	Annexure H (PARTICULARS OF THE BIDDER)				
24	ANNEXURE – L (INFORMATION CONTAINING DETAILS OF PROPOSAL)				
25	Form A & B				
26	ANNEXURE-C PERFORMA CERTIFICATE (No claim, No arbitration, To be submitted along with final bill)				
27	ANNEXURE – F BID FORM				

Form-A

List of qualifying staff to be submitted with physical documents

Sr.No.	NameofSupervisor	Qualification	Experience

Contractor /Authorized Representative's
Signature, Company's /Organization's Seal & Date

Note: Form-A of Bid without price shall be submitted with Part-1

Form-B

List of Tools & Tackles to be submitted with physical documents

Sr.No.	Description	Nos.	Status

Contractor /Authorized Representative's
Signature, Company's /Organization's Seal & Date

Note: Form-B of Bid without price shall be submitted with Part-1

ANNEXURE –J

SCHEDULE OF DEVIATION FROM GENERAL AND TECHNICAL SPECIFICATIONS

All the deviations from the general and technical specifications shall be filled by BIDDER clause by clause in this schedule.

Sr. No	SECTION	CLAUSE NO	AS PER TENDER DOCUMENT	DEVIATION

The bidder here by certifies that the above mentioned are the only deviations from OWNER's General/ Technical Conditions of this enquiry. The bidder further confirms that in the events any other data and information presented in the BIDDER's proposal and accompanying documents are at variance with specific requirements laid out in the OWNER's General /Technical Specifications, then the latter shall govern and will be binding on the BIDDER for quoted price.

COMPANY SEAL

SIGNATURE

NAME

DESIGNATION

COMPANY

DATE

ANNEXURE- M

(To be submitted on Company's Letter Head)

Declaration Cum Undertaking for Safety Laws and Regulations Compliance

I _____ on behalf ofName of Party/Company.....hereby confirm, agree and undertake that all the Statutory and Safety Laws and Regulations of the applicable Authority/ies shall be strictly followed for all types of works at the site during the period of the Contract, if awarded to me.

Further, IName of Party/Company..... also hereby confirm, declare and undertake that there has not been any major Safety Violation and any single Fatal Accident during the execution of the contract/contracts awarded to me during the period of preceding Three years.

Signed and Stamped by the
Authorized Signatory
Of the Bidder

ANNEXURE-N

Declaration for Contractual Disputes/ Litigations

(To be submitted on Company's Letter Head)

Please Tick (✓) whichever is correct option

I _____ on behalf ofName of Party/Company.....hereby confirm that I /We have

a. Not invoked legal recourse e.g. litigation against any Govt, of Gujarat Undertakings / Depts. / Authorities and Govt. of Gujarat supported companies / undertakings / organizations for the last three(03) years. There are no ongoing/pending legal matter(s) with any of the Govt. of Gujarat Undertakings / GoG supported Companies, including GIPCL.

Please Tick ()

OR

b. Invoked legal recourse e.g. litigation against any Govt, of Gujarat Undertakings / Depts. / Authorities and Govt. of Gujarat supported companies / undertakings / organizations for the last three(03) years.

Please Tick ()

If “b” is applicable, please submit the details for the same.

The above is true, as on date, to the best of my knowledge. Any breach/ false statement in this regard shall amount to disqualification of the Bid being submitted herein.

Signed and Stamped by the
Authorized Signatory
Of the Bidder

“Servicing/Overhauling of selected Soot Blowers of Unit-2 & Unit-3 Boilers and inspection & required servicing of selected Soot Blowers of Unit – 1 to 4 Boilers for the period of one-year 2025-26”.

ANNEXURE-H

PARTICULARS OF THE BIDDER

Sr. No.	Particulars	Please provide information here.
1.	Name of Bidder	
2.	a. Registered Office Address: b. Address for Correspondence: c. E-mail ID:	
3.	Contact Details: Contact Person Name Telephone No. : Mobile No.:	
4.	Year of establishment PAN No. GSTNo	

COMPANY SEAL

SIGNATURE

NAME

DESIGNATION

COMPANY

DATE