

**CORREGENDUM -B**

ESP TENDER SLPP/MECH/BLR/ESP/REPL. &amp; REPAIR /2019-20

nProcure Tender ID : 383805

**SCHEDULE OF CLARIFICATION FROM GENERAL AND TECHNICAL SPECIFICATIONS**

<b><u>Sl. No</u></b>	<b><u>Page No.</u></b>	<b><u>Clause No.</u></b>	<b><u>As per Tender Specification</u></b>	<b><u>Tender Condition</u></b>	<b><u>Clarification</u></b>
<b><u>GENERAL Terms (e-Reverse Auction)</u></b>					
<b>1.</b>	11 of 127 & 118 of 127	Clause No. 5 & SECTION-A & SECTION-F ANNEXURE-I	ELIGIBILITY CRITERIA	<b>5.18 &amp; (18)</b> :For Up gradation of Three Phase TR set from existing single Phase TR set, Vendor need to give guarantee of net reduction of 20 % in SPM while operating field with 3 phase TR set with respect to field operating with single phase TR set of across particular field in which 3 Phase TR set installed.	<b>This clause is eliminated from eligibility criteria.</b>  Total No of Eligibility criteria before corrigendum : <b>18</b> Total No of Eligibility criteria After corrigendum : <b>17</b>